



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

INACTIVE

T004254

Inactive type Permit has no description information.

EXPIRES LAST DAY OF: DECEMBER 1998

OWNER OF OPERATOR (Co.#2136)

JAGS CARE
17970 W. Hobson Way
Blythe, CA 92225

EQUIPMENT LOCATION (Fac.#1477)

B B Travel Center
17970 W Hobsonway
Blythe, CA 922253356

Description:

DIESEL DISPENSING FACILITY consisting of:

FUEL TANKS

Tank No.	Material Stored	Volume (US Gallons)	Above/Underground
----------	-----------------	---------------------	-------------------

DISPENSING EQUIPMENT

Fuel Type	Quantity
Diesel	10

VAPOR CONTROL EQUIPMENT

Type	Equipment Name	Compliance
	N/A	G-70-

CONDITIONS:

1. This diesel dispensing facility is subject to District Rule 463 as well as all other applicable Rule and Regulations.

Fee Schedule: 5 (b)

Rating: 60000 gallons

SIC: 5541

SCC: 9999999

Location/UTM(Km):
725E/3273N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

JAGS CARE
17970 W. Hobson Way
Blythe, CA 92225

By: **COPY**
Brad Poiriez
Executive Director

2. Each petroleum product tank must be equipped with a permanent submerged fill pipe. A person shall not transfer or permit the transfer of petroleum products into these tanks by any means other than the permanent submerged fill pipe.

NOTE: Permit Number G004232 is for the Retail Gasoline Dispensing Facility.