



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

PERMIT TO OPERATE

T007973

Operation under this permit must be conducted in compliance with all information included with the initial application, initial permit condition, and conditions contained herein. The equipment must be maintained and kept in good operating condition at all times. This Permit to Operate or copy must be posted on or within 8 meters of equipment. If a copy is posted, the original must be maintained on site, available for inspection at all times.

EXPIRES LAST DAY OF: OCTOBER 2026

OWNER OF OPERATOR (Co.#31)

Southern California Gas Co. - MD
9400 Oakdale Avenue
Chatsworth, CA 91313

EQUIPMENT LOCATION (Fac.#65)

SCG - Newberry Springs
3 Miles So. of I40 on Fort Cady Road
Newberry Springs, CA 92365

Description:

ABOVEGROUND WASTE CONDENSATE VESSEL consisting of: ONE (1) 950 GALLON ABOVEGROUND WASTE CONDENSATE VESSEL, serving 7 IC Engines and designed to be emptied by gravity-fed into waste container. Equipment elevation is 1900 feet above sea level. Stack is 6.5 feet in height and 1-inch in diameter.

CONDITIONS:

1. This equipment shall be installed, operated and maintained in strict accord with those recommendations of the manufacturer/supplier and/or sound engineering principles in a manner consistent with good air pollution control practice for minimizing emissions. Unless otherwise noted, this equipment shall also be operated in accordance with all data and specifications submitted with the application for this permit.

[District Rule 1302(C)(2)(a)]

2. All of the components of this tank, including but not limited to tanks, flanges, seals, pipes, pumps, valves, meters, connectors, shall be maintained and operated so as to prevent fugitive vapor leaks, fugitive liquid leaks, and excess organic liquid drainage during transfer, storage and handling operations.

[District Rule 462(D)]

3. This condensate tank must be equipped with a permanent submerged fill pipe. A person shall not transfer or permit the transfer of condensate into this tank by any means other than the permanent submerged fill pipe.

Fee Schedule: 5 (a)

Rating: 1000 gallons

SIC: 4922

SCC: 30600503

Location/UTM(Km):
537E/3849N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

Southern California Gas Co. - MD
PO Box 2300, SC 9314
Chatsworth, CA 91313-2300

By: **COPY**
Eldon Heaston
Air Pollution Control Officer

[District Rule 1302(C)(2)(a)]

4. Owner/Operator shall log all shipments of condensate to other parties and the hauler of said condensate. Additionally, this log shall contain the mass (or volume) and the date of the condensate shipment. Log must be kept on-site for a minimum of five (5) years and provided to District, State or Federal personnel on request.

[District Rule 1302(C)(2)(a)]

5. This tank is limited to storing IC Engine condensate generated on-site by So Cal Gas Co.

[District Rule 1302(C)(2)(a)]

6. A facility wide Comprehensive Emission Inventory (CEI) for all emitted criteria and toxic air pollutants must be submitted to the District, in a format approved by the District, upon District request.

[District Rule 107(b), H&S Code 39607 & 44341-44342, and 40 CFR 51, Subpart A]