



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

PERMIT TO OPERATE

T009039

Operation under this permit must be conducted in compliance with all information included with the initial application, initial permit condition, and conditions contained herein. The equipment must be maintained and kept in good operating condition at all times. This Permit to Operate or copy must be posted on or within 8 meters of equipment. If a copy is posted, the original must be maintained on site, available for inspection at all times.

EXPIRES LAST DAY OF: NOVEMBER 2025

OWNER OF OPERATOR (Co.#646)

Walmart Inc. c/o APTIM
8725 Rosehill Road, Suite 450
Lenexa, KS 66215

EQUIPMENT LOCATION (Fac.#2689)

Walmart #2333 - Apple Valley
20251 Highway 18
Apple Valley, CA 92307

Description:

STORAGE TANKS, WASTE OIL consisting of: One (1) 800-gallon waste oil ASTs used to collect waste oil from on-site vehicle oil changing operations, one (1) 240-gallon waste oil AST used to collect waste oil from customers, and one (1) 300 gallon waste oil AST used to collect waste oil from customers.

CONDITIONS:

1. This equipment shall be installed, operated and maintained in strict accord with those recommendations of the manufacturer/supplier and/or sound engineering principles in a manner consistent with good air pollution control practice for minimizing emissions. Unless otherwise noted, this equipment shall also be operated in accordance with all data and specifications submitted with the application for this permit.

[District Rule 1302(C)(2)(a)]

2. The owner/operator shall strictly adhere to all Federal, State, and/or District rules and regulations which pertain to the storing, handling, transferring, transporting, and disposing of waste oils.

[District Rule 1302(C)(2)(a)]

3. Only crankcase and other waste oil shall be transferred and/or stored into/in this tank.

[District Rule 1302(C)(2)(a)]

4. All of the components of this tank, including but not limited to tanks, flanges, seals, pipes, pumps, valves, meters, connectors, shall be

Fee Schedule: 5 (a) Rating: 1100 gallons SIC: 5699 SCC: 30630006 Location/UTM(Km): 482E/3820N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

Walmart Inc. c/o APTIM
ATTN: Licensing Support

Lenexa, KS 66215

By: **COPY**
Brad Poiriez
Air Pollution Control Officer

maintained and operated so as to prevent fugitive vapor leaks, fugitive liquid leaks, and excess organic liquid drainage during transfer, storage and handling operations.

[District Rule 463(C)(3)]

5. The owner/operator shall maintain an operations log for this equipment, current and on-site (or at a central location) for a minimum of two (2) years, and this log shall be provided to District, State and/or Federal personnel, upon request. The log shall include, at a minimum, the information specified below:

- a. Record of liquids stored in this tank, verified by MSDS and by retention of the waste manifests issued upon disposal of waste oil.
- b. A log containing any repairs and maintenance conducted on this equipment.

[District Rule 463 (D)(1) and (D)(3)].