



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

PERMIT TO OPERATE

T009192

Operation under this permit must be conducted in compliance with all information included with the initial application, initial permit condition, and conditions contained herein. The equipment must be maintained and kept in good operating condition at all times. This Permit to Operate or copy must be posted on or within 8 meters of equipment. If a copy is posted, the original must be maintained on site, available for inspection at all times.

EXPIRES LAST DAY OF: MAY 2026

OWNER OF OPERATOR (Co.#502)

Soil Safe of California, Inc
12328 Hibiscus Avenue
Adelanto, CA 92301

EQUIPMENT LOCATION (Fac.#1188)

Soil Safe - Adelanto
12328 Hibiscus Avenue
Adelanto, CA 92301

Description:

STORAGE TANKS, OIL consisting of: Two manifolded storage tanks containing diesel #2 or "on-specification" recycled used oil. Tank is equipped with an integral electric heater powered by 3-Phase 460 AC Voltage electrical power.

EQUIPMENT

Capacity	Equipment Description
40	Two 20,000 gallon horizontal storage tanks (40,000 gallons total)

CONDITIONS:

1. This equipment shall be installed, operated and maintained in strict accord with those recommendations of the manufacturer/supplier and/or sound engineering principles in a manner consistent with good air pollution control practice for minimizing emissions. Unless otherwise noted, this equipment shall also be operated in accordance with all data and specifications submitted with the application for this permit.

[District Rule 1302(C)(2)(a)]

2. All of the components of this tank, including but not limited to tanks, flanges, seals, pipes, pumps, valves, meters, connectors, shall be maintained and operated so as to prevent fugitive vapor leaks, fugitive liquid leaks, and excess organic liquid drainage during transfer,

Fee Schedule: 5 (b)

Rating: 40000 gallons

SIC: 4953

SCC: 50410535

Location/UTM(Km):
464E/3825N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

Soil Safe of California, Inc
12328 Hibiscus Avenue
Adelanto, CA 92301

By: **COPY**
Eldon Heaston
Air Pollution Control Officer

storage and handling operations.
[District Rule 463(C)(3)]

3. The owner/operator shall log the amount of diesel fuel delivered to these tanks and the date of delivery. This log shall be maintained for two (2) years current and on-site, and shall be provided to District, State or Federal personnel upon request.
[District Rule 1320]

4. The owner/operator shall maintain a log of all inspections, repairs, and maintenance on equipment. Such logs or records shall be maintained at the facility for at least two (2) years and shall be available to the District upon request.
[District Rule 463]

5. A facility wide Comprehensive Emission Inventory (CEI) for all emitted criteria and toxic air pollutants must be submitted to the District, in a format approved by the District, upon District request.
[District Rule 107(b); H&S Code 39607 & 44341-44342; and 40 CFR 51, Subpart A]