



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

AUTHORITY TO CONSTRUCT

T012060

If construction is not completed by the expiration date of this permit, it may be renewed for one additional year upon payment of applicable fees. Any additional extension will require the written approval of the Air Pollution Control Officer. This Authority to Construct may serve as a temporary Permit to Operate provided the APCO is given prior notice of intent to operate and the Permit to Operate is not specifically denied.

EXPIRES LAST DAY OF: APRIL 2026

OWNER OF OPERATOR (Co. #2774)

KS Properties, Inc.
15655 US Highway 395
Victorville, CA 92394

EQUIPMENT LOCATION (Fac. #3500)

High Desert Truck Stop
15655 U.S. Hwy 395
Victorville, CA 92394

Description:

FUEL STORAGE TANK AND DISPENSING EQUIPMENT (CARB DIESEL) consisting of:

EQUIPMENT

Capacity	Equipment Description
0	Diesel Storage Tank No. 3
0	Bio-diesel Storage Tank No. 4
0	Diesel Exhaust Fluid Storage Tank No. 5

CONDITIONS:

1. This equipment shall be operated/maintained in strict accord with manufacturer's/supplier's recommendations and/or sound engineering principles. [Rule 204]
2. Any modifications or changes to the piping or control fittings of the vapor recovery system requires prior approval from the District. [Rule 204]
3. This bulk plant shall comply with all requirements of District Rule 462. [Rule 204]

Fee Schedule: 5 (b) Rating: 60000 gallons SIC: 5541 SCC: 40600135 Location/UTM(Km): 473E/3956N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

KS Properties, Inc.
15655 US Highway 395
Victorville, CA 92394

By: **COPY**
Brad Poiriez
Air Pollution Control Officer

4.Operation of this equipment shall be conducted in compliance with all data and specifications submitted with the application under which permit is issued unless otherwise noted below. [Rule 204]

5.The o/o shall prepare and maintain a log showing both the daily and summary of the throughput for the calendar year to date. The log shall be maintained on-site for two (2) years and be made available to the District upon request. [Rule 204]

6.This equipment shall only store and dispense CARB Low Sulfur Diesel fuel. [Rule 204]