



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

AUTHORITY TO CONSTRUCT

T015556

If construction is not completed by the expiration date of this permit, it may be renewed for one additional year upon payment of applicable fees. Any additional extension will require the written approval of the Air Pollution Control Officer. This Authority to Construct may serve as a temporary Permit to Operate provided the APCO is given prior notice of intent to operate and the Permit to Operate is not specifically denied.

EXPIRES LAST DAY OF: DECEMBER 2026

OWNER OF OPERATOR (Co.#202)

Victor Valley Union H S District
16350 Mojave Drive
Victorville, CA 92392

EQUIPMENT LOCATION (Fac.#4704)

VVUHS - Transportation
14801 South Mojave Drive
Victorville, CA 92392

Description:

TANK, WASTE OIL STORAGE consisting of: One, 1000 gallon capacity storage tanks for used, waste crankcase oil.

CONDITIONS:

1. This equipment shall be installed, operated, and maintained in strict accordance with those recommendations of the manufacturer/supplier and/or sound engineering principles in a manner consistent with good air pollution control practice for minimizing emissions. Unless otherwise noted, this equipment shall also be operated in accordance with all data and specifications submitted with the application for this permit.

[District Rule 204]

2. The owner/operator shall strictly adhere to all Federal, State, and/or District rules and regulations which pertain to the storing, handling, transferring, transporting, and disposing of waste oils.

[District Rule 204]

3. Only crankcase and other waste automotive oil shall be transferred into and/or stored in this tank, verified by records required in Condition #5(a).

[District Rule 204; District Rule 1320(B)]

Fee Schedule: 5 (a)

Rating: 1000 gallons

SIC: 4119

SCC: 30630006

Location/UTM(Km):
472E/3819N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

Victor Valley Union H S District
16350 Mojave Drive
Victorville, CA 92392

By: **COPY**
Brad Poiriez
Executive Director

4. All of the components of this tank, including but not limited to tanks, flanges, seals, pipes, pumps, valves, meters, connectors, shall be maintained and operated so as to prevent fugitive vapor leaks, fugitive liquid leaks, and excess organic liquid drainage during transfer, storage and handling operations.

[District Rule 463(C)(3)(a)]

5. The owner/operator shall maintain an operations log for this equipment, current and on-site (or at a central location) for a minimum of five (5) calendar years, and this log shall be provided to District, State and/or Federal personnel, upon request. The log shall include, at a minimum, the information specified below:

a. Record of liquids stored in this tank, verified by SDS and by retention of the waste manifests issued upon disposal of waste oil.

b. A log containing any inspections, repairs, and maintenance conducted on this equipment.

[District Rule 463 (D)(1) and (D)(3)]

6. This Emissions Unit is limited to an annual waste oil throughput of 500,000 gallons per calendar year, verified by records produced in accordance with Condition #5(a). These records are to be made available to District Staff upon request.

[District Rule 204]

7. This tank is to be inspected by the owner/operator not less than once per calendar month to ensure there are no leaks, damage, or uncontrolled venting.

[District Rule 463(C)(3)(f)]

8. A facility wide Comprehensive Emission Inventory (CEI) for all emitted criteria and toxic air pollutants must be submitted to the District, in a format approved by the District, upon District request.

[District Rule 107(b); H&S Code 39607 & 44341-44342; 17 CCR 93400 et seq.; 40 CFR 51, Subpart A]