



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

INACTIVE

B000173

Inactive type Permit has no description information.

EXPIRES LAST DAY OF: MAY 2008

OWNER OF OPERATOR (Co.#2239)

CalPortland Company
19409 National Trails Hwy
Oro Grande, CA 92368

EQUIPMENT LOCATION (Fac.#3)

CalPortland Oro Grande
19409 National Trails Hwy
Oro Grande, CA 92368

Description:

KILN AND CLINKER SYSTEM NO. 4 (140) consisting of:

EQUIPMENT

Capacity	Equipment Description
7.5	23-054 Screw Conveyor No. 54
10	44-017 Elevator No. 7 to Kiln 4
5	44-034 Screw Conveyor No. 14 to SC 13
4	44-047,048 Screw Conveyors; 2: Nos. 27 and 28 @ 2 hp each
10	44-059,064 Screw Conveyors; 2: Nos. 39 and 44 @ 5 hp each
150	44-164 Kiln No. 4, 130 MMBTUH
15	44-174 Cooler (10 and 5 hp)
75	44-179 Cyclone, Buell
30	44-194 Heat Exchanger (3 @ 10 hp)
100	44-214,224 Fans; 2: Cooler @ 75 and 27 hp
25	44-234 Clinker Breaker
250	44-244 Coal Mill, CM 64
2.5	44-254 Feeder Belt, Coal Mill
1.5	44-264 Valve, Coal Mill
0	Total EQ HP + MMBTUH = 1.7 + 130 = 131.7

Fee Schedule: 8 (f)

Rating: 131700000 Btu

SIC: 3241

SCC: 99999999

Location/UTM(Km): 469E/3830N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

CalPortland Company
Attn: Catalina Elias

Oro Grande, CA 92368

By: **COPY**

Brad Poiriez

Air Pollution Control Officer

CONDITIONS:

1.This equipment must not be operated unless it is vented to operating air pollution control equipment covered by valid District permit C000174 (44-152).

2.The owner/operator (o/o) shall comply with all District Rules and Regulations including, but not limited to, malfunction/breakdown notifications.

3.The o/o shall have a continuing program of maintenance/inspections in accord with manufacturer's recommendations and specifications which ensures compliance with District Rules.

4.The o/o shall maintain a log of all inspections, repairs and maintenance on this equipment and submit it to the District upon request. The log shall be kept for a minimum period of two years.

5.Daily logs shall be maintained for the operation of kiln No. 4 which includes but is not limited to the following:

- A. Hours of operation/day,
- B. Dates of major repairs and/or replacements,
- C. Type of fuel being used and the Btu/h of each,
- D. Dates of routine repairs.

6.The o/o shall comply with all requirements of Rule 1161 (Portland Cement Kilns) and provide to the District the following:

A. The daily emissions for each operating day for this kiln system shall be recorded and/or calculated in a manner approved by the District. The data shall be submitted to the District within 30 days of the end of each calendar quarter.

B. The o/o shall submit a written report of excess emisisions to the District Compliance supervisor for every calendar quarter. All quarterly reports shall be postmarked by the 30th day following the end of each calendar quarter.