MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT
14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

INACTIVE

B000232

Inactive type Permit has no description information.

EXPIRES LAST DAY OF: AUGUST 2010

OWNER OF OPERATOR (Co.#3254)

5E SVM Operations, LLC
13200 Main Street
Trona, CA 93562

EQUIPMENT LOCATION (Fac.#7)

SVM - West End Plant
80201 Trona Road
Trona, CA 93562

Description:
BOILER NO. 1 consisting of: Natural gas fired; maximum rating of 86 x 10 6 btu/h. This boiler is designed to produce 60,000 lb of steam per hour at 250 psig at a fuel flow rate of 72,000 ft 3/h through Wickes burners.

CONDITIONS:

1. The owner/operator (o/o) shall conduct annual emission tests relative to District Rules 476 and 407. Test results shall be submitted to the District not later than six weeks prior to the expiration date of this permit.

2. The o/o shall have a continuing program of maintenance/inspections in accord with manufacturer's recommendations and specifications which ensures compliance with District rules. Logging of data shall be required with the log kept on-site for a minimum of two years. This log shall be provided to District personnel on request.

Fee Schedule: 2 (e) | Rating: 59400000 Btu | SIC: 1474 | SCC: 99999999 | Location/UTM(Km): 464E/3951N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

5E SVM Operations, LLC
P.O. Box 367
Trona, CA 93592-0367

By: **COPY**
Brad Poiriez
Executive Director

UNOFFICIAL