



## MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310  
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

### AUTHORITY TO CONSTRUCT

B000955

If construction is not completed by the expiration date of this permit, it may be renewed for one additional year upon payment of applicable fees. Any additional extension will require the written approval of the Air Pollution Control Officer. This Authority to Construct may serve as a temporary Permit to Operate provided the APCO is given prior notice of intent to operate and the Permit to Operate is not specifically denied.

**EXPIRES LAST DAY OF: NOVEMBER 2025**

#### OWNER OF OPERATOR (Co. #86)

MAGTFTC MCAGCC  
Box 788110, Bldg 1418  
Twentynine Palms, CA 92278-8110

#### EQUIPMENT LOCATION (Fac. #3252)

USMC AGCC - USMC Utilities  
Box 788110, Bldg. 1451  
Twentynine Palms, CA 92278

#### Description:

BOILER - NO. 2, DUAL FUEL, HIGH TEMPERATURE HOT WATER (BLDG 1577) consisting of: an International Lamont Generator, model TJW-P-40, serial number 15694, equipped with American Combustion Technologies Super Low NOx burner with heat input rating of 51.2 millions Btu/hr, model ACT-08-G02-SLE with flue gas recirculation (FGR) and electronic modulation. Primary fuel is Natural Gas; Backup Fuel is #2 Fuel Oil.

#### EQUIPMENT

Capacity	Equipment Description
50	International Lamont Generator (50 MMBtu/hr)
0.03	Circulation Pump (15 hp)
0.12	High Temperature Water Distribution Pump (50 hp)
0.06	Combustion Air Blower (25 hp)
0.01	Fuel Oil Pump (7.5 hp)

#### CONDITIONS:

1. Operation of this equipment shall be conducted in compliance with all data and specifications submitted with the application under which this permit is issued unless otherwise noted below.

Fee Schedule: 2 (e)

Rating: 50220000 Btu

SIC: 9711

SCC: 10300602

Location/UTM(Km): 587E/3788N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

MAGTFTC MCAGCC  
Box 788110, Building 1418  
  
Twentynine Palms, CA 92278-8110

By: **COPY**  
**Brad Poiriez**  
Air Pollution Control Officer

2.This equipment shall be installed, operated and maintained in strict accord with those recommendations of the manufacturer/supplier and/or in a manner consistent with safety and good air pollution control practices for minimizing emissions.

3.This boiler is limited to firing pipeline regulated natural gas and No. 2 fuel oil as a backup. This unit may be fired on No. 2 fuel oil for testing or during curtailment of natural gas supply only. [District Rule 431]

4.Fuel oil sulfur concentration must not exceed 0.0015% on a weight per weight basis. Compliance must be demonstrated through the retention of the following;

- a. The name of the oil supplier;
  - b. A statement from the oil supplier that the oil complies with the specifications under the definition of distillate oil in 40 CFR Part 60.41c; and
  - c. The sulfur content or maximum sulfur content of the oil.
- [District Rule 431 and 40 CFR 60.42c (d)]

5.This unit shall not exceed the following emission limits, verified through an initial compliance test, in accordance with Rule 1157. All values corrected to 3% oxygen:

- a. Carbon monoxide: 100 ppmv;
  - b. NOx: 9ppmv, and/or 0.011 lbs/MMBtu of heat input, when operated on gaseous fuel;
  - c. NOx: 100 ppmv, and/or 0.150 lbs/MMBtu of heat input, when operated on liquid fuels at loads varying from 25 to 100%.
- [Rule 1303]

6.Initial compliance tests shall be conducted within 90 days of initial operation and shall follow the procedures stipulated in District Rule 1157. Owner/operator shall provide written notification to the District at a minimum 10 days prior to conducting the test. Written test results shall be provided to the District within 45 days of completion of the test.

7.This equipment shall be tested to determine compliance with the above limits through emission compliance testing, according to Rule 1157, not less than once every twelve (12) months. A tune-up may be performed in lieu of a compliance test for years when the annual heat input is less than 50,000 MMBtu. The boilers with valid District permits B000955, B011795, and M011794 represent three like boilers. If the combined annual heat input is above 50,000 MMBtu, then the emission limits and annual testing apply to all units. [District Rule 1157]

8.The operator shall maintain a log for this equipment, which, at a minimum, contains the information specified below. This log shall be maintained current and on-site for a minimum of two (2) years and shall be provided to District personnel on request:

- a. Annual fuel use (MMcf) or heat input (MMBtu), on a calendar year basis;
- b. Annual compliance test or tune-up verification;
- c. Gaseous and Liquid fuel sulfur content (fuel supplier certifications).

9.The boilers with valid District permits B000955, B011795, and M011794 represent three like boilers, one of which is a standby unit. No more than two of the three boilers covered by these permits can be operated simultaneously, except for one hour during start-up of one boiler and ramp-down/shut-down of another boiler.

10.In each calendar year, the actual emissions of this facility shall be less than 20 tons NOx, 20 tons VOC, and 12 tons PM10 (SM80 Emission Rate). O/o shall demonstrate compliance with this limit on an annual basis through the submission of the Comprehensive Emission Inventory Report (CEIR) to the District. Copies of the CEIR(s) must be kept and maintained on-site for at least five years and presented to District personnel upon request. [District Rule 221]