



# MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310  
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

**INACTIVE**

B002661

Inactive type Permit has no description information.

**EXPIRES LAST DAY OF: AUGUST 2005**

## **OWNER OF OPERATOR (Co.#15)**

Pacific Gas & Electric/Air Permits  
PO Box 28150  
Oakland, CA 94604-8150

## **EQUIPMENT LOCATION (Fac.#535)**

PG&E - Hinkley Compressor Station  
35863 Fairview Road  
Hinkley, CA 92347

### **Description:**

DIESEL IC ENGINE GENERATOR consisting of: Caterpillar Model D 348, Serial No. 36J2507, 755 hp (5.451 MMBtu/hr) turbocharged V-12, diesel fuel consumption of 271.8 lb/hr, supplemental.

### **CONDITIONS:**

1. The owner/operator (o/o) shall operate this equipment in strict accord with the manufacturer's specification and/or sound engineering principles.
2. The o/o shall maintain a log of all inspections, repairs and maintenance on this equipment and submit it to the District upon request. The log shall be kept for a minimum of two (2) years.

Fee Schedule: 1 (c)

Rating: 755 bhp

SIC: 4939

SCC: 20100102

Location/UTM(Km):  
485E/3862N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

Pacific Gas & Electric/Air Permits  
PO Box 28150  
Oakland, CA 94604-8150

By: **COPY**  
**Brad Poiriez**  
Executive Director