



## MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310  
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

### PERMIT TO OPERATE

B003238

Operation under this permit must be conducted in compliance with all information included with the initial application, initial permit condition, and conditions contained herein. The equipment must be maintained and kept in good operating condition at all times. This Permit to Operate or copy must be posted on or within 8 meters of equipment. If a copy is posted, the original must be maintained on site, available for inspection at all times.

#### EXPIRES LAST DAY OF: NOVEMBER 2024

#### OWNER OF OPERATOR (Co. #86)

MAGTFTC MCAGCC  
Box 788110, Bldg 1418  
Twentynine Palms, CA 92278-8110

#### EQUIPMENT LOCATION (Fac. #3245)

USMC AGCC - USN Naval Hospital  
Box 788110, Bldg. 1451  
Twentynine Palms, CA 92278

#### Description:

BOILER - No. 1 (BLDG 1145, BASE HOSPITAL) consisting of: a Kewanee Steam Boiler, model H3S-150-GO, serial number 10469, equipped with a Cleaver Brooks model NTH080-GX-9S-4 serial number 59827-1 low NOx (9ppmv @ 3% O<sub>2</sub>) burner rated at 6.25 MMBtu/hr heat input. The burner may be fired on natural gas or No. 2 fuel oil.

#### EQUIPMENT

Capacity	Equipment Description
62.78	Kewanee Steam Boiler (6.25 MMBtu/hr)
0.01	Circulation Pump (0.75 hp)
0.07	High Temperature Water Distribution Pump (3 hp)
0.12	Induced Draft Fan (5 hp)
0.12	Combustion Air Blower (5 hp)
0.01	Fuel Oil Pump (0.5 hp)

#### CONDITIONS:

1. Operation of this equipment shall be conducted in compliance with all data and specifications submitted with the application under which this permit is issued unless otherwise noted below.

Fee Schedule: 2 (d)

Rating: 6250000 Btu

SIC: 9711

SCC: 10300603

Location/UTM(Km): 587E/3788N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

MAGTFTC MCAGCC  
Box 788110, Building 1418  
Twentynine Palms, CA 92278-8110

By: **COPY**  
Brad Poiriez  
Air Pollution Control Officer

2.This equipment shall be installed, operated and maintained in strict accord with those recommendations of the manufacturer/supplier and/or sound engineering principles which produce the minimum emissions of contaminants.

3.This boiler is limited to firing pipeline regulated natural gas and No. 2 fuel oil as a backup. This unit may be fired on No. 2 fuel oil for testing or during curtailment of natural gas supply only. [Rule 431.1]

4.The operator shall maintain a log for this equipment, which, at a minimum, contains the information specified below. This log shall be maintained current and on-site for a minimum of two (2) years and shall be provided to District personnel on request:

- a. Annual fuel use (MMcf) or heat input (MMBtu), on a calendar year basis;
- b. Annual compliance test or tune-up verification;
- c. Liquid fuel sulfur content (fuel supplier certifications).

5.This unit shall meet the following emission limits (corrected to 3% oxygen):

- a. Carbon monoxide not to exceed 50 ppmv and/or 0.15 lb/MMBtu;
- b. NOx not to exceed 9 ppmv and/or 0.011 lb/MMBtu.

[Rule 1303(A); Rule 1157]

6.This equipment shall be tested to determine compliance with the above limits through emission compliance testing, according to Rule 1157, not less than once every twelve (12) months. A tune-up may be performed in lieu of a compliance test for years when the annual heat input is less than 50,000 MMBtu. The boilers with valid District permits B003238 and M003239 represent two identical boilers. If the combined annual heat input is above 50,000 MMBtu, then the emission limits and annual testing apply to all units.

7.The boilers with valid District permits B003238, and M003239 represent two identical boilers, one of which is a standby unit. No more than one of the two boilers covered by these permits can be operated simultaneously, except for one hour during start-up of one boiler and ramp-down/shut-down of another boiler.