



**MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT**

14306 Park Avenue Victorville, CA 92392-2310  
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

**INACTIVE**

B003463

Inactive type Permit has no description information.

**EXPIRES LAST DAY OF: NOVEMBER 2006**

**OWNER OF OPERATOR (Co.#88)**

NAWS  
429 E Bowen Road - Stop 4014  
China Lake, CA 93555-6108

**EQUIPMENT LOCATION (Fac.#567)**

NAWCWD Test Stands  
429 E Bowen Road - Stop 4014  
China Lake, CA 935556108

**Description:**

I.C.E. - GENERATOR consisting of: at VARIOUS LOCATIONS ON THE FACILITY, a Consolidated genset, model MEP007A; engine model D33 and rated at 170 bhp. The Navy serial number is K-108.

**CONDITIONS:**

1. This I.C. Engine shall only burn diesel fuel; No. 1 or No. 2 fuel oil; JP-5; or JP-8.
2. All fuels burned by this I.C. Engine shall not contain sulfur in excess of 0.05% by weight.
3. The owner/operator (o/o) shall require from the supplier analytical results relating to the sulfur content of the fuel delivered and shall not accept delivery whenever the sulfur concentration exceeds 0.05% by weight.
4. The o/o shall maintain copies of these delivery results on-site and provide them to District personnel on request.
5. An operations log shall be maintained on-site for at least two (2) years and be made available to District personnel on request. This log shall contain, as a minimum the total hours operated each day, and if an "Hour Meter" is available the reading at the beginning and end of each day; and the date and amount (gallons) of fuel delivery.
6. This I.C. Engine shall only be operated/maintained in strict accord with manufacturer's/supplier's recommendations and/or sound engineering principles.

Fee Schedule: 1 (b)

Rating: 170 bhp

SIC: 9711

SCC: 9999999

Location/UTM(Km):  
450E/3946N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

<p>NAWS Environmental Management Division  China Lake, CA 93555-6108</p>
--------------------------------------------------------------------------------------

By: **COPY**  
**Eldon Heaston**  
 Air Pollution Control Officer