



## MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310  
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

**INACTIVE**

B003761

Inactive type Permit has no description information.

**EXPIRES LAST DAY OF: NOVEMBER 2006**

### **OWNER OF OPERATOR (Co.#84)**

NTC - Public Works  
Bldg 602, 5th Street  
Fort Irwin, CA 92310

### **EQUIPMENT LOCATION (Fac.#3280)**

NTC Public Works and Building Maintenance  
AFZJ-PW-EV, Bldg 602  
Fort Irwin, CA 92310

#### **Description:**

BOILER, LPG (BLDG 253) consisting of: a Rite Model Number 500 LPG-fired boiler with Serial Number 8218698 and rated 5.0 MMBtu/hr.

#### **CONDITIONS:**

1. The o/o shall maintain a current, on-site (at a central location if necessary) log for this equipment for two (2) years, which shall be provided to District, State or Federal personnel upon request. This log shall include calendar year fuel use for this equipment in standard cubic feet, gallons, or Btus.
2. The owner/operator (o/o) shall operate this equipment in strict accord with the recommendations of the manufacturer or supplier and/or sound engineering principles and consistent with all information submitted with the application for this permit which produce the minimum emission of air contaminants.
3. This boiler shall use only propane or liquified propane gas (LPG) as fuel and shall be equipped with a meter measuring propane consumption in standard cubic feet or gallons.
4. Equipment with valid District permits B003761 and M004347 shall not be operated concurrently and shall not exceed 21,900 MMBtu of heat input per year (combined).

Fee Schedule: 2 (d)

Rating: 5000000 Btu

SIC: 7349

SCC: 10301002

Location/UTM(Km): 511E/3861N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

NTC - Public Works  
Attn: Air Resources Manager  
  
Fort Irwin, CA 92310

By: **COPY**  
**Brad Poiriez**  
Air Pollution Control Officer