



**MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT**

14306 Park Avenue Victorville, CA 92392-2310  
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

**INACTIVE**

B003893

Inactive type Permit has no description information.

**EXPIRES LAST DAY OF: NOVEMBER 1998**

**OWNER OF OPERATOR (Co.#88)**

NAWS  
429 E Bowen Road - Stop 4014  
China Lake, CA 93555-6108

**EQUIPMENT LOCATION (Fac.#567)**

NAWCWD Test Stands  
429 E Bowen Road - Stop 4014  
China Lake, CA 935556108

**Description:**

INTERNAL COMBUSTION ENGINE consisting of: at various locations on the facility, a CYM generator, model UZ00491, driven by an engine rated at 170 bhp.

**CONDITIONS:**

1. Operation of this equipment shall be conducted in compliance with all data and specifications submitted with the application under which this permit is issued unless otherwise noted below.
2. This unit shall be fired with only Nos. 1 or 2, JP-5 or-8 fuels, whose sulfur concentrations are less than 0.05% on a weight per weight basis, without the prior written approval of the APCO.
3. The owner/operator, o/o, shall log the starting and stopping times of the operational periods of this generator, to the nearest minute, and the date. The o/o shall log all purchases of fuel (with the sulfur content) including the volume (or weight), and the date received. The log shall be maintained current, on-site for a minimum of 2 years and provided to District personnel on request.
4. The equipment shall be operated and maintained in strict accord with the manufacturer/supplier and/or sound engineering principles which produce the minimum of contaminants.

Fee Schedule: 1 (b)

Rating: 170 bhp

SIC: 9711

SCC: 9999999

Location/UTM(Km):  
450E/3946N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

NAWS  
Environmental Management Division  
  
China Lake, CA 93555-6108

By: **COPY**  
Eldon Heaston  
Air Pollution Control Officer