



## MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310  
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

**INACTIVE**

**B003942**

Inactive type Permit has no description information.

**EXPIRES LAST DAY OF: MARCH 2022**

### **OWNER OF OPERATOR (Co.#603)**

Luz Solar Partners LTD., VIII  
437 Madison Avenue 22nd Floor, Suite A  
New York, NY 10022

### **EQUIPMENT LOCATION (Fac.#975)**

Harper Lake SEGS VIII  
43880 Harper Lake Road  
Hinkley, CA 92347

#### **Description:**

HEAT TRANSFER FLUID (HTF) ULLAGE SYSTEM, SEGS VIII consisting of:

#### **EQUIPMENT**

Capacity	Equipment Description
0	Pump, Ullage Vessel - 15 gpm @ 160 psig, 30 hp @ 3520 rpm
0	Pump, Ullage Cooler Circulation - 3 hp @ 1750 rpm
0	Cooler, Ullage - E-399, 204600 Btu/hr @ 180 psig & 560 degrees F
0	Cooler, Ullage - E-400, 650000 Btu/hr @ 180 psig & 560 degrees F
0	Vessel, Ullage - V-373, 2000 gal @ 180 psig & 500 degrees F
0	Vessel, Ullage Second - V-374, 2000 gal @ 15 psig & 250 degrees F
0	Vessel, Ullage Drain - V-377, 3000 gal @ 15 psig

#### **CONDITIONS:**

1. All equipment shall be maintained and operated in strict accord with recommendations of the manufacturer/supplier and/or sound engineering principles.

2. If current non-criteria substances become regulated as toxic or hazardous substances and are used in this equipment, the owner/operator shall submit to the District a plan demonstrating how compliance will be achieved and maintained with such regulations.

Fee Schedule: 7 (i)

Rating: 1 device

SIC: 4911

SCC: 99999999

Location/UTM(Km): 469E/3876N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

Luz Solar Partners LTD., VIII  
437 Madison Avenue 22nd Floor, Suite A  
New York, NY 10022

By: **COPY**  
**Brad Poiriez**  
Air Pollution Control Officer