



## MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310  
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

**INACTIVE**

B004006

Inactive type Permit has no description information.

**EXPIRES LAST DAY OF: JANUARY 1999**

### **OWNER OF OPERATOR (Co.#122)**

SKANSKA USA Civil West Region  
1995 Agua Mansa Road  
Riverside, CA 92509-2405

### **EQUIPMENT LOCATION (Fac.#1696)**

SKANSKA - Wild Wash  
I-15 at Wild Wash Road  
Victorville, CA 92392

#### **Description:**

INTERNAL COMBUSTION ENGINE consisting of:

One Caterpillar, Diesel fired internal combustion engine Model No. D399 and Serial No. , producing 1310 bhp with cylinders at rpm while consuming a maximum of . This equipment powers a Generator Model No. and Serial No. , rated at 800 kW.

#### **CONDITIONS:**

1. This equipment shall not operate more than 11 hours in any one day, from midnight to midnight.
2. This equipment shall use no other fuel but diesel without prior written approval of the APCO.
3. The sulfur content of the fuel used in this equipment shall not exceed 0.05% on a mass basis. The owner/operator (o/o) shall log the volume or mass and the dates of all purchases of fuel and the sulfur content. The o/o may use the supplier's sulfur analytical data, but at the discretion of the District, shall take a sample of the fuel and submit it for analysis by ASTM method D-2622 or D-4294 as they may be amended from time to time. An independent laboratory analysis shall be logged and forwarded to the District on receipt.
4. The o/o shall log the hours of operation of this unit to the nearest one-quarter hour. This log shall be maintained current, on-site and provided to District personnel on request.

Fee Schedule: 1 (d)

Rating: 1310 bhp

SIC: 2951

SCC: 9999999

Location/UTM(Km):  
481E/3739N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

SKANSKA USA Civil West Region  
1995 Agua Mansa Road  
Riverside, CA 92509-2405

By: **COPY**  
**Brad Poiriez**  
Executive Director

5. This engine shall have 4 degree retarded timing for BACT.

6. The o/o shall comply with all applicable Rules and Regulations of the District; particularly Rule 1160 in its entirety. To this end, within 90 days of start-up of this equipment (pursuant to condition 5 on District Permit B005034), the o/o shall meet with District staff to formulate a test plan. Within 180 days of start-up of this equipment, the o/o shall conduct emission tests as described in Section (F) of District Rule 1160. Submittal of the final emission test report to the District shall be no more than 45 days following the last day of on-site sampling and measurements.