



## MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310  
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

**INACTIVE**

B004407

Inactive type Permit has no description information.

**EXPIRES LAST DAY OF: NOVEMBER 1998**

### **OWNER OF OPERATOR (Co.#69)**

Southern California Edison  
P.O. Box 5085  
Rosemead, CA 91770

### **EQUIPMENT LOCATION (Fac.#1525)**

SCE - AVAQMD - Var Locations/inactive  
District Wide  
MDAQMD, CA 92392

#### **Description:**

PORTABLE INTERNAL COMBUSTION ENGINE consisting of: Cummins, Model No. 6CTA8.3G, Serial No. 44550283, 6 cylinder, 277 bhp diesel fired IC engine which drives an electric generator.

#### **CONDITIONS:**

1. The owner/operator (o/o) shall log all starting and stopping times of the test periods of this generator, to the nearest minute; the date; and the delivery of fuel.
2. The o/o shall comply with all applicable rules and regulations of the District.
3. The o/o shall not use diesel fuel whose sulfur concentration is greater than 0.05% on a w/w basis.
4. The o/o shall not use any fuel in this generator other than diesel without the prior written approval of the District. The o/o may use the supplier's sulfur analytical data, but at the discretion of the District, shall take a sample of the fuel and submit it for analysis by an independent laboratory. The results of said analyses, by ASTM method D 2622-82, shall be logged.
5. The o/o shall maintain the logs current, on-site for a minimum of 2 years and provide them to District personnel on request.

Fee Schedule: 1 (c)

Rating: 277 bhp

SIC: 4911

SCC: 20100102

Location/UTM(Km): 473E/3956N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

Southern California Edison  
P.O. Box 5085

Rosemead, CA 91770

By: **COPY**  
**Brad Poiriez**  
Air Pollution Control Officer