



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA92392-2310
760.245.1661 -- 800.635.4617 -- FAX760.245.2022

INACTIVE

B004575

Inactive type Permit has no description information.

EXPIRES LAST DAY OF: SEPTEMBER 2006

OWNER OF OPERATOR (Co.#834)

Joshua Basin Water District
PO Box 675
Joshua Tree, CA92252

EQUIPMENT LOCATION (Fac.#1574)

Joshua Basin Water Dist - Plaza & Sunburst
Plaza & Sunburst
Joshua Tree, CA92252

Description:

IC ENGINE, EMERGENCY GENERATOR consisting of:

OneWaukesha, NG fired internal combustion engine Model No. L3711GU and Serial No. 48695, Other, Other, producing 618 bhp with 12 cylinders at 1200 rpm while consuming a maximum of 30.0 scf/hr. This equipment powers a Pump Model No. and Serial No., rated at.

CONDITIONS:

1. The owner/operator, o/o, shall not fire this equipment on any fuel but pipeline regulated natural gas without the prior written approval of the APCO.
2. The o/o shall not operate this unit without a properly functioning catalytic converter.
3. The o/o shall operate and maintain this engine and its catalytic converter in strict accord with the recommendations of the manufacturers and/or sound engineering principles.
4. This unit shall be limited to use for emergency power, defined as when commercially available power has been interrupted, and as part of a testing program which does not exceed 4 hours per month.
5. A timer shall be installed and maintained on this unit to indicate elapsed operating time.
6. The o/o shall maintain a log for this unit, which, at a minimum, contains the information specified below. This log shall be maintained

Fee Schedule: 7 (g) Rating: 1 device SIC: 4941 SCC: 20100202 Location/UTM(Km): 565E/3778N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

Joshua Basin Water District
PO Box 675
Joshua Tree, CA92252

By: **COPY**
Brad Poiriez
Air Pollution Control Officer

current and on-site for a minimum of two (2) years and shall be provided to District personnel on request.

- a. Date of each use;
- b. Duration of each use, in minutes; and,
- c. Annual operation in terms of calendar year fuel use (in cubic feet) or hours.