



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

INACTIVE

B004581

Inactive type Permit has no description information.

EXPIRES LAST DAY OF: APRIL 1998

OWNER OF OPERATOR (Co.#69)

Southern California Edison
P.O. Box 5085
Rosemead, CA 91770

EQUIPMENT LOCATION (Fac.#945)

SCE - Victorville
12353 Hesperia Road
Victorville, CA 92392

Description:

PORTABLE ELECTRICITY GENERATOR consisting of: a unit that is gas fired, rated at 120 bhp, and will be used to pump water at various locations in the District. The engine that powers the unit is a Continental Engine, Red Seal Model , SN F400A421S.

One Continental, 89U fired internal combustion engine Model No. Red Seal and Serial No. F400A421S, producing 120 bhp with 4 cylinders at rpm while consuming a maximum of . This equipment powers a Model No. and Serial No. , rated at .

EMISSIONS RATES

Emission Type	Est. Max Load	Unit
CO	6.3	
NOx	0.16	
PM10	0.01	
SOx	0.008	
VOC	0.33	

CONDITIONS:

1. Operation of this equipment shall be conducted in compliance with all data and specifications submitted with the application under which this permit is issued unless otherwise noted below.

Fee Schedule: 1 (c)

Rating: 120 bhp

SIC: 4911

SCC: 20300301

Location/UTM(Km):
473E/3820N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

Southern California Edison
P.O. Box 5085

Rosemead, CA 91770

By: **COPY**
Brad Poiriez
Executive Director

2. This equipment shall use no other fuel but unleaded gasoline without the prior written approval of the APCO.
3. The o/o shall comply with all applicable rules and regulations of this District.
4. The o/o shall log the hours of operation of this unit to the nearest one-quarter hour. This log shall be maintained current, on-site and provided to District personnel on request.
5. This unit shall not be used more than 70 hours in any calendar year.