



# MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310  
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

## INACTIVE

B004645

Inactive type Permit has no description information.

**EXPIRES LAST DAY OF: FEBRUARY 2000**

### OWNER OF OPERATOR (Co.#100)

Metropolitan Water District of So Calif  
158000 MWD Road  
Parker Dam, CA 92267

### EQUIPMENT LOCATION (Fac.#571)

MWD - Gene Pumping Plant  
158000 MWD Road  
Parker Dam, CA 92267

#### **Description:**

COMPRESSOR consisting of: Ingersoll-Rand, Model VC 200IR LD-136, Serial No 38160, driven by a Cummins 200 bhp, six cylinder diesel IC engine consuming 8.5 gal per hour of fuel at 1800 rpm.

#### **CONDITIONS:**

1. The owner/operator (o/o) shall log all starting and stopping times for this unit, to the nearest quarter-hour; the date; and the delivery of fuel.
2. The o/o shall comply with all applicable rules and regulations of the District.
3. The o/o shall not use diesel fuel whose sulfur concentration is greater than 0.05% on a weight basis.
4. The o/o shall not use any fuel in this generator other than diesel without the written prior approval of the District. The o/o may use the supplier's sulfur analytical data, but at the discretion of the District, shall take a sample of the fuel and submit it for analysis by an independent laboratory. The results of said analyses, by ASTM Method D 2622-82, shall be logged.
5. The o/o shall maintain all required logs current, on-site for a minimum of two (2) years and provide them to District personnel on request.
6. This unit shall not be operated more than 7500 hours in a calendar year without prior written approval of the District APCO.

Fee Schedule: 1 (b)      Rating: 200bhp      SIC: 4941      SCC: 99999999      Location/UTM(Km): 761E/3798N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

Metropolitan Water District of So Calif  
P O Box 54153  
  
Los Angeles, CA 90054

By: **COPY**  
**Brad Poiriez**  
Air Pollution Control Officer