



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

INACTIVE

B004649

Inactive type Permit has no description information.

EXPIRES LAST DAY OF: APRIL 2004

OWNER OF OPERATOR (Co.#427)

Molded Fiber Glass Companies West
9400 Holly Road
Adelanto, CA 92301

EQUIPMENT LOCATION (Fac.#1095)

Molded Fiber Glass - Holly Rd
9400 Holly Road
Adelanto, CA 92301

Description:

BOILER - STEAM consisting of: Ajax Mfg. With ancillary equipment. This unit model No. SNG-50 is described as a natural gas fired steam boiler rated at 1.995 x 10 6 BTU/h. This unit will produce the power to drive the presses described in District permits B004646 through B004648.

CONDITIONS:

1. This unit shall fire no other fuel except regulated pipeline gas without the written permission of the APCO.
2. The owner/operator shall log the volume of natural gas fired by this unit on a calendar monthly basis. This log shall be maintained current, on-site and provided to District personnel on request.
3. The o/o shall ensure that this unit has been provided with its own dedicated gas meter prior to installation and use of this unit.

Fee Schedule: 2 (c)

Rating: 2000000 Btu

SIC: 3088

SCC: 99999999

Location/UTM(Km):
459E/2836N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

Molded Fiber Glass Companies West
9400 Holly Road
Adelanto, CA 92301

By: **COPY**
Eldon Heaston
Air Pollution Control Officer