



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

INACTIVE

B004682

Inactive type Permit has no description information.

EXPIRES LAST DAY OF: NOVEMBER 2006

OWNER OF OPERATOR (Co.#87)

Commanding Officer, MCLB Barstow, CA
Box 110570 Bldg 196 Attn: Air Program Manager
Barstow, CA 92311-5050

EQUIPMENT LOCATION (Fac.#1177)

USMC MCLB - Nebo Annex
USMC Logistics Base
Barstow, CA 923115013

Description:

WASTEWATER TREATMENT FACILITY located at Bldg 325 consisting of:

EQUIPMENT

Capacity	Equipment Description
4	Pumps, sludge - 2 @ 2 hp ec.
0	Digester
0	Sludge Lagoon No 1
0	Sludge Lagoon No 2

CONDITIONS:

1. Operation of this equipment shall be conducted in compliance with data and specifications submitted with the application under which this permit is issued unless otherwise noted below.
2. This system shall be used concurrently with the Digester Heater covered by District permit B004193 and the Digester Flare covered by District permit C004191.

Fee Schedule: 1 (a)

Rating: 4 bhp

SIC: 9711

SCC: 9999999

Location/UTM(Km):
505E/3859N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

Commanding Officer, MCLB Barstow, CA
Box 110570 Attn: Air Program Manager
Barstow, CA 92311-5050

By: **COPY**
Eldon Heaston
Air Pollution Control Officer

3. An operation log shall be maintained on-site for at least two (2) years and be made available to District personnel on request. This log shall contain, as a minimum, the amount of wastewater received and treated each day.

4. This equipment shall be operated/ maintained in strict accord with manufacturer's/supplier's recommendations; sound engineering principles; and/or federal, state, regional and local waste water discharge permits.