



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA92392-2310
760.245.1661 -- 800.635.4617 -- FAX760.245.2022

INACTIVE

B004787

Inactive type Permit has no description information.

EXPIRES LAST DAY OF: NOVEMBER 2003

OWNER OF OPERATOR (Co.#84)

NTC - Public Works
Bldg 602, 5th Street
Fort Irwin, CA92310

EQUIPMENT LOCATION (Fac.#589)

NTC Training Mission
Bldg. 602, 5th street
Fort Irwin, CA923105085

Description:

IC ENGINE, ELECTRICITY GENERATOR consisting of: Field Support Site. Coleman internal combustion engine model 6059TF4001 serial number T06059T407817 rated at 166 bhp and drives a generator by Coleman/Newage model CJST110SQ serial number 12931552 rated at 110 kW(e). This engine burns less than 7.0 gallons of fuel per hour at maximum bhp. The fuel storage tank, which is above ground, has a capacity of 500 gallons.

CONDITIONS:

1. This engine shall only burn diesel fuel and/or JP-8.
2. The sulfur content of the fuel used in this engine shall not exceed 0.05% on a mass basis. The owner/operator (o/o) shall log the volume or mass and the dates of all purchases of fuel and the sulfur content. The o/o may use the supplier's sulfur analytical data, but at the discretion of the District, shall take a sample of the fuel and submit it for analysis by ASTM method D-2622 or D-4294 as they may be amended from time to time. An independent laboratory shall conduct the analyses. The results of said analyses shall be logged and forwarded to the District on receipt.
3. The o/o shall log the times of operation to the nearest 1/4 hour and the date this unit is used. Also, the log shall contain the dates of fuel delivery and the volume (or weight) delivered. The log shall be maintained current, on-site for a minimum of two (2) years and provided to District personnel on request.
4. The o/o shall comply with all applicable rules and regulations of the District.
5. This engine shall be operated/maintained in strict accord with manufacturer's/supplier's recommendations and/or sound engineering

Fee Schedule: 1 (b) Rating: 166bhp SIC: 9711 SCC: 99999999 Location/UTM(Km): 529E/3902N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

NTC - Public Works
Attn: Air Resources Manager

Fort Irwin, CA92310

By: **COPY**
Brad Poiriez
Air Pollution Control Officer

principles which produce the minimum emissions.