



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

INACTIVE

B004874

Inactive type Permit has no description information.

EXPIRES LAST DAY OF: APRIL 2003

OWNER OF OPERATOR (Co.#427)

Molded Fiber Glass Companies West
9400 Holly Road
Adelanto, CA 92301

EQUIPMENT LOCATION (Fac.#1095)

Molded Fiber Glass - Holly Rd
9400 Holly Road
Adelanto, CA 92301

Description:

BOILER - STEAM consisting of: a Cleaver Brooks, model CBI-700-125LE low NOx, serial number L-97257. This unit is rated at 125 boiler horsepower and is fired on regulated pipeline natural gas. The rated heat input is 5.1 millions Btu/h.

CONDITIONS:

1. The o/o shall ensure that this unit has been provided with its own dedicated gas meter prior to installation and use of this unit.
2. This unit shall fire no other fuel except regulated pipeline gas without the written permission of the APCO.
3. The o/o shall operate all equipment described in this permit in strict accord with the recommendations of the manufacturer or supplier and/or sound engineering principles and consistent with all information submitted with the application for this permit which produce the minimum emission of air contaminants.
4. This equipment shall be operated in compliance with all data and specifications submitted with the application under which this permit is issued unless otherwise noted herein.
5. The o/o shall maintain a log for this equipment, which, at minimum, contains the information specified below. This log shall be maintained current and on-site for a minimum of two (2) years and shall be provided to District personnel on request:
 - a. Annual fuel use (in MMcf and/or gallons) or heat input (in MMBtu); and
 - b. Tune-up verification.

Fee Schedule: 2 (d)

Rating: 5100000 Btu

SIC: 3088

SCC: 10300603

Location/UTM(Km):
459E/2836N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

Molded Fiber Glass Companies West
9400 Holly Road
Adelanto, CA 92301

By: **COPY**
Eldon Heaston
Air Pollution Control Officer

6. This equipment shall be tuned not less than once every twelve (12) months, or otherwise operated according to Rule 1157 for low annual heat input units (less than 50,000 MMBtu/year).