



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

INACTIVE

B005139

Inactive type Permit has no description information.

EXPIRES LAST DAY OF: APRIL 1999

OWNER OF OPERATOR (Co.#1049)

Bakersfield Well & Pump
7212 Fruitvale Avenue
Bakersfield, CA 93308

EQUIPMENT LOCATION (Fac.#1850)

Bakersfield Well & Pump
District Wide
MDAQMD, CA 92392

Description:

INTERNAL COMBUSTION ENGINE consisting of: a diesel fired, 6-cylinder Cummins engine, model NTA855P which is rated at 335 bhp at 1800 rpm. This engine is direct injected, turbocharged, after-cooled and has the ignition timing retarded. The engine burns diesel fuel at the rate of 15.0 gal/h, maximum.

CONDITIONS:

1. Operation of this equipment shall be conducted in compliance with all data and specifications submitted with the application under which this permit is issued unless otherwise noted below.
2. This equipment shall use no other fuel but diesel without the prior written approval of the APCO.
3. The sulfur content of the fuel used in this equipment shall not exceed 0.05% on a mass basis. The owner/operator, o/o, shall log the volume or mass and the dates of all purchased fuel and the sulfur content. The o/o may use the supplier's sulfur analytical data, but at the discretion of the District, shall take a sample of the fuel and submit it for analysis by ASTM method D-2622 of D-4294 as they may be amended from time to time. An independent laboratory shall conduct the analyses. The results of said analyses shall be logged and forwarded to the District on receipt.
4. The o/o shall comply with all applicable rules and regulations of this District.

Fee Schedule: 1 (c)

Rating: 335 bhp

SIC: 4941

SCC: 20200102

Location/UTM(Km):
459E/3826N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

Bakersfield Well & Pump
7212 Fruitvale Avenue
Bakersfield, CA 93308

By: **COPY**
Eldon Heaston
Air Pollution Control Officer

5. The o/o shall log the hours of operation of this unit to the nearest one-quarter hour and its annual fuel use. This log shall be maintained current, on-site and provided to District personnel on request.

6. This unit shall not be operated more than 6300 hours in the District in any calendar year without prior written approval of the District APCO.