



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

INACTIVE

B005335

Inactive type Permit has no description information.

EXPIRES LAST DAY OF: APRIL 2000

OWNER OF OPERATOR (Co.#1259)

J & S Painting, Inc
296 E Parr Blvd
Reno, NV 89512

EQUIPMENT LOCATION (Fac.#2178)

J & S Painting Inc
USMC AGCC
Twentynine Palms, CA 922788110

Description:

AIR COMPRESSOR consisting of:

One John Deere, Diesel fired internal combustion engine Model No. 375 OPO 2W6D and Serial No. 004-93801-E1-6, Direct Injected, Turbo Charged, Inter Cooled, Ignition Retarded, producing 102 bhp with 4 cylinders at 2500 rpm while consuming a maximum of 28.0 lbs/hr. This equipment powers a Sullair Compressor Model No. 375 OPO 2W6D and Serial No. 004-93801-E1-6, rated at 375 cfm.

EMISSIONS RATES

Emission Type	Est. Max Load	Unit
CO	4.13	gm/bhp-hr
HC	0.32	gm/bhp-hr
NOx	8.25	gm/bhp-hr

CONDITIONS:

1. Operation of this equipment shall be conducted in compliance with all data and specifications submitted with the application under which this permit was issued unless otherwise noted below.

2. All equipment shall be maintained and operated in strict accord with recommendations of the manufacturer/supplier and/or accepted engineering principles

Fee Schedule: 1 (b)

Rating: 102 bhp

SIC: 7699

SCC: 99999999

Location/UTM(Km):
586E/3778N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

J & S Painting, Inc
296 E Parr Blvd
Reno, NV 89512

By: **COPY**
Eldon Heaston
Air Pollution Control Officer

3. The owner/operator (o/o) shall use only diesel fuel whose sulfur concentration is equal or less than 0.05% on a weight basis. The o/o may use the supplier's furnished certification of sulfur content if the certifications are maintained on file.

4. This equipment does not require a regularly scheduled emission compliance test. However, emission compliance testing may be required at the discretion of the District.

5. The o/o shall maintain a log for this unit, which, at a minimum, contains the information specified below. This log shall be maintained current and on-site for a minimum of two (2) years and shall be provided to District personnel on request:

- a. Date of each use;
- b. Duration of each use, in minutes;
- c. Fuel consumed during each calendar year, in gallons;
- d. Fuel sulfur concentration