



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA92392-2310
760.245.1661 -- 800.635.4617 -- FAX760.245.2022

INACTIVE

B005347

Inactive type Permit has no description information.

EXPIRES LAST DAY OF: APRIL 2000

OWNER OF OPERATOR (Co.#69)

Southern California Edison
P.O. Box 5085
Rosemead, CA91770

EQUIPMENT LOCATION (Fac.#96)

SCE - Solar II
East Santa Fe Road
Daggett, CA92327

Description:

SALT PRILLING EQUIPMENT consisting of:

EQUIPMENT

Capacity	Equipment Description
0	Prill header, Prilling tower, and prill bottom hopper
1	Conveyor, 20 ft.
1	Conveyor, 20 ft.
1	Conveyor, 24 ft.
20	Fluidbed; 5 sq. ft. screen area; 300 fpm/sq. ft. air velocity; 1500 ACFM total flow.
20	Fluidbed; 5 sq. ft. screen area; 300 fpm/sq. ft. air velocity; 1500 ACFM total flow.

CONDITIONS:

- 1.Operation of this equipment shall be conducted in compliance with all data and specifications submitted with the application under which this permit is issued unless otherwise noted below.
- 2.The owner/operator (o/o) shall operate and maintain this equipment in strict accord to recommendations of the manufacturer/supplier and/or sound engineering practices.
- 3.Material may not be processed through the fluid beds or put into the maxi-bags unless the Prilling System is vented into an operating

Fee Schedule:1 (b) Rating:43bhp SIC:9711 SCC:9999999 Location/UTM(Km):591E/3856N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

Southern California Edison
P.O. Box 5085

Rosemead, CA91770

By: **COPY**
Brad Poiriez
Air Pollution Control Officer

baghouse which has been issued valid Permit C005348 by the District.

4.The operating instructions shall be immediately available for use by the operator and provided to District personnel upon request.

5.The o/o shall have a continuing program of maintenance/inspections in accord with manufacturer's recommendations and specifications which ensures compliance with District Rules.

6.This equipment does not require a regularly scheduled emission compliance test. However, emission compliance testing may be required at the discretion of the District.