

MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park AvenueVictorville,CA92392-2310 760.245.1661 -- 800.635.4617 -- FAX760.245.2022

PERMIT TO OPERATE

B007889

Operation under this permit must be conducted in compliance with all information included with the initial application, initial permit condition, and conditions contained herein. The equipment must be maintained and kept in good operating condition at all times. This Permit to Operate or copy must be posted on or within 8 meters of equipment. If a copy is posted, the original must be maintained on site, available for inspection at all times.

EXPIRES LAST DAY OF:NOVEMBER 2025

OWNER OF OPERATOR (Co.#1657)

CH2M Hill Services P.O. Box 10450 Fort Irwin,CA92310

EQUIPMENT LOCATION (Fac.#2806)

Fort Irwin Wastewater Treatment Plant Wastewater Treatment Plant, Bldg 700 Fort Irwin,CA92310

Description:

WASTEWATER TREATMENT PLANT, DISINFECTION PRODUCTION SYSTEM consisting of:A sodium hypochlorite system with two pumps, dual headed, 1.50 hp, 240 vac each, operating at 45 rpm, one brine tank, containing 20 tons of salt, and two 1200 gallon tanks.

CONDITIONS:

1. The owner/operator (o/o) shall operate and maintain all equipment described in this permit in strict accord with all the submittals attendant with the application and/or sound engineering principles.

Fee Schedule:7 (i)	Rating:1device	SIC:9511	SCC:50100701	Location/UTM(Km):511E/3861N
This permit does not	t authorize the emission	of air contaminants in	excess of those allowed by law,	including Division 26 of
the Health and Safe	ty Code of the State of 0	California and the Rule	es and Regulations of the District	. This permit cannot be

the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

CH2M Hill Services P.O. Box 10450

Fort Irwin, CA92310



Brad Poiriez Air Pollution Control Officer