



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

INACTIVE

B008551

Inactive type Permit has no description information.

EXPIRES LAST DAY OF: NOVEMBER 2006

OWNER OF OPERATOR (Co.#84)

NTC - Public Works
Bldg 602, 5th Street
Fort Irwin, CA 92310

EQUIPMENT LOCATION (Fac.#3280)

NTC Public Works and Building Maintenance
AFZJ-PW-EV, Bldg 602
Fort Irwin, CA 92310

Description:

BOILER, LPG (BLDG 298) consisting of: a Raytherm Model WH-2500, Serial # 0207196919 boiler (water heater). This boiler is fired on liquified propane gas and is rated at 2.499 MMBtu/hr of heat input. This boiler is equipped with a one hp Armstrong recirculation pump (137 gal/minute) and a 53 gallons Wessels TXA-200 thermal expansion tank (150 PSIG).

CONDITIONS:

1. This boiler shall use only propane or liquified propane gas (LPG) as fuel and shall be equipped with a meter measuring propane consumption in standard cubic feet or gallons.
2. The o/o shall maintain a current, on-site (at a central location if necessary) log for this equipment for two (2) years, which shall be provided to District, State or Federal personnel upon request. This log shall include calendar year fuel use for this equipment in standard cubic feet, gallons, or Btus.
3. This boiler shall not consume more than 5,473 MMBtu of fuel per calendar year.
4. The owner/operator (o/o) shall operate this equipment in strict accord with the recommendations of the manufacturer or supplier and/or sound engineering principles and consistent with all information submitted with the application for this permit which produce the minimum emission of air contaminants.

Fee Schedule: 2 (c)

Rating: 2499000 Btu

SIC: 7349

SCC: 10301002

Location/UTM(Km):
511E/3861N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

NTC - Public Works
Attn: Air Resources Manager

Fort Irwin, CA 92310

By: **COPY**
Brad Poiriez
Executive Director