



**MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT**

14306 Park Avenue Victorville, CA92392-2310  
760.245.1661 -- 800.635.4617 -- FAX760.245.2022

**INACTIVE**

B009800

Inactive type Permit has no description information.

**EXPIRES LAST DAY OF:OCTOBER 2009**

**OWNER OF OPERATOR (Co.#1654)**

New Cingular Wireless PCS, LLC  
311 S. Akard Street, 12th Floor  
Dallas, TX75202

**EQUIPMENT LOCATION (Fac.#2926)**

AT&T - Havasu Landing II  
1469 Havasu Lake Rd  
Needles, CA92363

**Description:**

DIESEL IC ENGINE, PRIMARY ELECTRICAL GENERATOR consisting of:Year of MFG 1998

OneCummins,Diesel fired internal combustion engine Model No.4BT3.9G and Serial No.45045579,Direct Injected,Turbo Charged, producing92 bhp with4 cylinders at1800 rpm while consuming a maximum of5.0gal/hr. This equipment powers aOnanGenerator Model No.50QSGCA and Serial No.G9450550415, rated at50 kw.

**EMISSIONS RATES**

Emission Type	Est. Max Load	Unit
CO	0.89	gm/bhp-hr
HC	0.43	gm/bhp-hr
NOx	11.8	gm/bhp-hr
PM10	0.25	gm/bhp-hr
SOx	0.63	gm/bhp-hr

**CONDITIONS:**

1.This equipment shall be installed, operated and maintained in strict accord with those recommendations of the manufacturer/supplier and/or sound engineering principles which produce the minimum emissions of contaminants. Unless otherwise noted, this equipment shall also be operated in accordance with all data and specifications submitted with the application for this permit.

Fee Schedule:1 (b)      Rating:92bhp      SIC:4813      SCC:20200102      Location/UTM(Km):729E/3817N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

New Cingular Wireless PCS, LLC  
ATTN: EH&S  
  
Dallas, TX75202

By: **COPY**  
**Brad Poiriez**  
Air Pollution Control Officer

2.This unit shall only be fired on ultra-low sulfur diesel fuel, whose sulfur concentration is less than or equal to 0.0015% (15) on a weight per weight basis per CARB Diesel or equivalent requirements.

3.A non-resettable four-digit (9,999) hour timer shall be installed and maintained on this unit to indicate elapsed engine operating time. (17 CCR \S93115(e)(4)(G)1.)

4.The o/o shall maintain a operations log for this unit current and on-site (or at a central location) for a minimum of three (3) years, and this log shall be provided to District, State and Federal personnel upon request. The log shall include, at a minimum, the information specified below:

- a. Date of each use and duration of each use (in hours);
- b. Calendar year operation in terms of fuel consumption (in gallons) and total hours; and,
- c. Fuel sulfur concentration (the o/o may use the supplier's certification of sulfur content if it is maintained as part of this log).

5.The Diesel Particulate Matter emission from this diesel ICE must comply with one of the three following options by the appropriate compliance date in either Conditions 7 or 8:

Option 1. 85% reduction in emissions from baseline levels. (17 CCR \S93115(e)(1)(D)1.a.)

Option 2. 0.01 g/bhp hr (17 CCR \S93115(e)(1)(D)1.b.)

Option 3. 30% reduction in emissions from baseline levels by 1/1/2006 and 0.01 g/bhp hr by 7/1/2011. (17 CCR \S93115(e)(1)(D)1.c.)

6.The hydrocarbon (HC), oxides of nitrogen (NOX), non-methane hydrocarbons plus NOX (NMHC+NOx) and carbon monoxide (CO) emissions from this diesel ICE must comply with one of the three following options by the appropriate compliance date in either condition 7 or 8:

Option 1. Use verified emission control strategy. (17 CCR \S93115(e)(1)(D)2. and see 13 CCR \S2700-2710 for procedure)

Option 2. Emissions standards for off-road engines of the same model year and rated power as specified in 13 CCR \S2423 or "Tier 1" standards if no such standards exist. (17 CCR \S93115(e)(2)(D)2.a.)

Option 3. No more than 10% increase in HC or NOx from baseline or no increase in NMHC+NOx from baseline AND no more than 10% increase in CO from baseline. (17 CCR \S93115(e)(2)(D)2.a.)

7.Owner/Operators of 3 or fewer diesel fueled ICEs within the District must comply with applicable requirements by the following dates:

Pre 1989 - 1989 model year engines comply by 1/1/2006. (17 CCR (f)(2)(A))

1990 - 1995 model year comply by 1/1/2007. (17 CCR \S93115(f)(2)(B))

1996 - 2004 model year comply by 1/1/2008. (17 CCR \S93115(f)(2)(C))

[Note: 2005 engines are considered "new" (17 CCR \S193115(g)(2)).]

8.Owner/Operators of 4 or more diesel fueled ICEs within the District must comply with applicable requirements with the following percentage of engines by the following dates:

Pre 1989 - 1989 model year engines:

50% of engines comply by 1/1/2007

70% of engines comply by 1/1/2008

100% of engines comply by 1/1/2009

1990 - 1995 model year engines:

30% of engines comply by 1/1/2007

60% of engines comply by 1/1/2008

100% of engines comply by 1/1/2009

1996 - 2004 model year engines:

50% of engines comply by 1/1/2008

100% of engines comply by 1/1/2009

[Note: 2005 engines are considered "new" (17 CCR \S193115(g)(2)).]

9.The owner/operate must submit the required control strategy to District for compliance with emissions limitations 6 months prior to the appropriate compliance date(s) in either Conditions 7 or 8. The control strategy must contain the health risk assessment to show compliance with Condition 11. (17 CCR \S93115(e)(4)(A)4.)

10.The owner/operate must submit the required emissions data to District prior to appropriate compliance date(s) in either Conditions 7 or 8 for the engine. (17 CCR \S93115(e)(4)(D))

11.Since equipment is remotely located (more than 1 mile from another receptor) and the prioritization score is less than 1.0 and/or the cancer risk is less than 1.0 in and million and the hazard index is less than 0.1 the equipment must comply this conditions 5 and 6 on or before January 1, 2011. Submit required health risk assessment as part of Condition 9. (17 CCR \S93115(c)(18))

12.The owner/operate must notify the District immediately upon the loss of the exemption in Condition 11. (17 CCR \S93115(e)(4)(F)1.)

13.The owner/operator of this equipment shall demonstrate compliance with the requirements Conditions 5 and 6 within 180 days of notifying the District or notification from the District of the lose of an exemption. (17 CCR \S93115(e)(4)(F)2.)

14.This diesel fired ICE is subject to the requirements of the Airborne Toxic Control Measure (ATCM) for Stationary Compression Ignition Engines (17 CCR 93115). In the event of conflict between these conditions and the ATCM, the requirements of the ATCM shall govern.