



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

INACTIVE

B009925

Inactive type Permit has no description information.

EXPIRES LAST DAY OF: APRIL 2009

OWNER OF OPERATOR (Co.#2)

CALNEV Pipe Line, LLC
1001 Louisiana Street
Houston, TX 77002-5089

EQUIPMENT LOCATION (Fac.#2853)

CALNEV- Various Locations
District Wide
MDAQMD, CA 92392

Description:

PRIMARY, PORTABLE IC ENGINE, PROPANE consisting of: Yr of Mfg (tbd), Approx. 1/2 mi No of Basin Rd Exit off I - 15

One Generac/General Motors, Propane fired internal combustion engine Model No. DG-505 and Serial No. 3702849, Other, Other, producing 74 bhp with 8 cylinders at 1800 rpm while consuming a maximum of 2.0 gal/hr. This equipment powers a Generac Generator Model No. 004595-0/004596-0 and Serial No. 3702849, rated at 50 kW.

CONDITIONS:

1. This equipment shall be installed, operated and maintained in strict accord with those recommendations of the manufacturer/supplier and/or sound engineering principles which produce the minimum emissions of contaminants.
2. Operation of this equipment shall be conducted in accordance with all data and specifications submitted with the application under which this permit is issued unless otherwise noted below.
3. This unit shall only be fired on Propane or Natural Gas fuel.
4. The owner/operator (o/o) shall maintain a operations log for this unit current and on-site, either at the engine location or at a on-site location, for a minimum of five (5) years, and for another year where it can be made available to the District staff within 5 working days from the District's request, and this log shall be provided to District, State or Federal personnel upon request. The log shall include, at a minimum, the information specified below:
 - a. Date of each use and duration of each use (in hours);

Fee Schedule: 1 (b)

Rating: 74 bhp

SIC: 4959

SCC: 20100202

Location/UTM(Km):
473E/3956N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

CALNEV Pipe Line, LLC
1001 Louisiana Street

Houston, TX 77002-5089

By: **COPY**
Eldon Heaston
Air Pollution Control Officer

- b. Reason for use (testing & maintenance, emergency, required emission testing);
 - c. Calendar year operation in terms of fuel consumption (in gallons or equivalent) and total hours; and,
 - d. Fuel sulfur concentration (the o/o may use the supplier's certification of sulfur content if it is maintained as part of this log).
5. A non-resettable four-digit (9,999) hour timer shall be installed and maintained on this unit to indicate elapsed engine operating time.
6. This unit shall only provide power to existing soil remediation equipment, MDAQMD permit # C009561 and including all associated plant rehabilitation program equipment such as, but not limited to, water pumps.