



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

INACTIVE

B010552

Inactive type Permit has no description information.

EXPIRES LAST DAY OF: NOVEMBER 2009

OWNER OF OPERATOR (Co.#84)

NTC - Public Works
Bldg 602, 5th Street
Fort Irwin, CA 92310

EQUIPMENT LOCATION (Fac.#589)

NTC Training Mission
Bldg. 602, 5th street
Fort Irwin, CA 923105085

Description:

DIESEL IC ENGINE, PORTABLE consisting of: @ BLDG 659 Yr of Mfg 1996, Tier 0 Engine

One Cummins, Diesel fired internal combustion engine Model No. 4B3.9-C and Serial No. 45338034, Direct Injected, Turbo Charged, producing 76 bhp with 4 cylinders at 1800 rpm while consuming a maximum of . This equipment powers a Power Mark Conveyor Model No. 336001 and Serial No. 96031051, rated at .

EMISSIONS RATES

Emission Type	Est. Max Load	Unit
CO	3.303	gm/bhp-hr
NOx	14.074	gm/bhp-hr
PM10	0.999	gm/bhp-hr
SOx	0.931	gm/bhp-hr
VOC	0.003	gm/bhp-hr

CONDITIONS:

1. This equipment shall be installed, operated and maintained in strict accord with those recommendations of the manufacturer/supplier and/or sound engineering principles which produce the minimum emissions of contaminants. Unless otherwise noted, this equipment shall also be operated in accordance with all data and specifications submitted with the application for this permit.

Fee Schedule: 1 (b)

Rating: 76 bhp

SIC: 9711

SCC: 20200102

Location/UTM(Km):
529E/3902N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

NTC - Public Works
Attn: Air Resources Manager

Fort Irwin, CA 92310

By: **COPY**
Brad Poiriez
Executive Director

2. This diesel ICE and its associated equipment cannot be operated at the same engine-print (spot) for more than 365 consecutive days. (This system must be moved within this facility or moved to another facility annually.) [Title 13 CCR 93116.2(bb)]

3. This unit shall only be fired on diesel fuel with sulfur concentration less than or equal to 0.0015% or 15 ppm per CARB Diesel or equivalent requirements; or alternative diesel fuel or CARB diesel fuel utilizing fuel additives that has been verified through the Verification Procedure for In-Use Strategies to Control Emissions from Diesel Engines. [Title 13 CCR 93116.3(a)]

4. A non-resettable four-digit (9,999) hour timer shall be installed and maintained on this unit to indicate elapsed engine operating time by January 1, 2012. [Title 13 CCR 93116.4(c)(2)(A)]

5. Prior to January 1, 2010, this portable diesel-fueled engine (unit) or its replacement engine shall be certified to meet a federal or California standard for newly manufactured nonroad engines pursuant to 40 CFR Part 89 or Title 13 CCR Section 2423 (that is, certified to Tier 1, 2 or 3 nonroad engine standards). Unless, this unit is used exclusively for emergency applications or qualifies as a low-use engine (operates 80 hours or less per calendar year) and the o/o commits to replacing this engine with a Tier 4 engine. (Tier 4 engines are phased in for engines manufactured beginning in 2011). (Title 17 CCR Section 93116.3 (b)(1))

6. The o/o shall maintain a operations log for this unit current and on-site (or at a central location) for a minimum of five (5) years, and this log shall be provided to District, State and Federal personnel upon request. The log shall include, at a minimum, the information specified below:

- a. Record the operating hour meter readout monthly;
- b. Calendar year operation in terms of fuel consumption (in gallons) and total hours; and,
- c. Fuel sulfur concentration (the o/o may use the supplier's certification of sulfur content if it is maintained as part of this log). [Title 13 CCR 93116.4(c)]
- d. The log should contain the following statement; "This diesel ICE and its associated equipment cannot be operated at the same engine-print (spot) for more than 365 consecutive days."

7. The o/o of this unit must submit a Status Report for the entire fleet* by March 1, 2011. This Status Report should include, but not limited to, the following, for details see Title 13 CCR 93116.4(e)(1):

- a. The fleet's weighted average PM emission rate for the 2010 calendar year,
- b. Inventory of portable engines in the fleet,
- c. Identify, if applicable, each portable diesel-fueled engine that the owner commits to replacing with a Tier 4 engine,
- d. Listing of portable diesel-fueled engines, if applicable, used exclusively in emergency applications,
- e. Listing of portable diesel-fueled engines, if applicable, satisfying the low-use engine requirements,
- f. Listing of portable alternative-fueled engines, if applicable, added to the fleet prior to January 1, 2009, pursuant to section 93116.3(d)(2)(B)2, and
- g. Listing of portable diesel-fueled engine(s) equipped with Selective Catalytic Reduction (SCR) system(s),

* Fleet is defined in Title 17 CCR Section 93116.2(p) as one or more portable unit(s).

8. The fleet* under control of this o/o is subject to and shall comply with the weighted Diesel Particulate Matter (DPM) emission fleet averages** expressed as grams per brake horsepower-hour (g/bhp-hr) of Title 17 CCR Section 93116.3(c) & (d) by the following dates:

Compliance Date Weighted DPM (g/bhp-hr)
January 1, 2013 0.30

January 1, 2017 0.18

January 1, 2020 0.04

* Fleet is defined in Title 17 CCR Section 93116.2(p) as one or more portable unit(s).

** The method used to calculate the Fleet Average is found in Title 13 CCR 93116.3(d).

9. The o/o of this unit must submit a Statement of Compliance signed by the Responsible Official that the fleet standards are being achieved and a summary that identifies each portable engine in the fleet and the associated emission rate (g/bhp-hr) and other required information, see Title 13 CCR 93116.4(e)(2), (3), (4), (5), (6) and (7) for the following compliance statement submittal dates:

Weighted DPM Emission Fleet Average Date Submit by

January 1, 2013 March 1, 2013

January 1, 2017 March 1, 2017

January 1, 2020 March 1, 2020

10. The o/o of fleets that are exempted from the requirements of section 93116.4 pursuant to section 93116.4 (a), the Responsible Official shall certify that all portable diesel-fueled engines in the fleet satisfy the requirements of section 93116.4(a). See Title 13 CCR 93116.4(f) for details.

11. The o/o and/or Responsible Official of a fleet electing to use electrification in determining the fleet average shall submit the report required by title 13 CCR 93116.4(c)(3) by January 1, 2012.

12. This unit is subject to the requirements of the Airborne Toxic Control Measure (ATCM) for Portable Compression Ignition Engines (Title 13 CCR 93116). In the event of conflict between these conditions and the ATCM, the more stringent requirements shall govern.

13. This equipment shall not operate more than 10 hours per any single 24 hour period (one-day).

14. This equipment shall not operate more than 3650 hours per year, defined as 365 days consecutive days.