



## MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310  
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

**INACTIVE**

B011918

Inactive type Permit has no description information.

**EXPIRES LAST DAY OF: APRIL 2026**

### **OWNER OF OPERATOR (Co.#1509)**

Nursery Products, LLC  
P.O. Box 1439  
Helendale, CA 92342

### **EQUIPMENT LOCATION (Fac.#2571)**

Nursery Products, LLC  
14479 Cougar Road  
Helendale, CA 92342

#### **Description:**

DIESEL IC ENGINE, PORTABLE TROMMEL SCREEN consisting of: Portable Trommel Screen with a throughput rating of 39 TPH. Equipment includes a certified Tier 3 Compression-Ignition (Diesel) Prime Use Engine, EPA Family AMBXL07.2RJA with no exhaust after-treatment system. This equipment may be operated anywhere within the area known as Nursery Products, LLC, 14479 Cougar Road, Helendale, CA 92342. Exhaust stack is estimated at 12 foot high with a 0.3 foot diameter. PERP Registration Number: NONE

One Mercedes Benz, Diesel fired internal combustion engine Model No. OM904LA and Serial No. 904.975-00-860517, Compression-Ignited, Direct Injected, Inter Cooled, Turbo Charged, producing 101 bhp with 4 cylinders at 2200 rpm while consuming a maximum of 5.2 gal/hr. This equipment powers a Doppstadt Screen Model No. SM 720 and Serial No. 449, rated at 177 cubic feet feed volume.

#### **EMISSIONS RATES**

Emission Type	Est. Max Load	Unit
CO	1.34	gm/bhp-hr
NOx	2.55	gm/bhp-hr
PM10	0.13	gm/bhp-hr
SOx	0.005	gm/bhp-hr
VOC	0.13	gm/bhp-hr

#### **CONDITIONS:**

Fee Schedule: 1 (b)

Rating: 1 bhp

SIC: 4953

SCC: 20100102

Location/UTM(Km):  
459E/3826N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

Nursery Products, LLC  
P.O. Box 1439  
Helendale, CA 92342

By: **COPY**  
**Brad Poiriez**  
Executive Director

1. This certified portable diesel internal combustion engine shall be installed, operated and maintained in strict accordance with those recommendations of the manufacturer/supplier and/or sound engineering principles which produce the minimum emissions of contaminants. Unless otherwise noted, this equipment shall also be operated in accordance with all data and specifications submitted with the application for this permit. [District Rule 1302]
  
2. This diesel ICE and its associated equipment cannot be operated at the same engine-print (spot) for more than 365 consecutive days. This system must be moved for a valid business purpose annually. [Title 17 CCR 93116.2(a)(29), District Rules 1302, 1303, and 1320]
  
3. This unit shall only be fired on ultra-low sulfur diesel fuel whose sulfur concentration is less than or equal to 0.0015% (15 ppm) per CARB Diesel or equivalent requirements; or alternative diesel fuel or CARB diesel fuel utilizing fuel additives that has been verified through the Verification Procedure for In-Use Strategies to Control Emissions from Diesel Engines. [Title 17 CCR 93116.3(a)]
  
4. A non-resettable four-digit (9,999) hour timer shall be installed and maintained on this unit to indicate elapsed engine operating time. [Title 17 CCR 93116.4(c)(2)(A)]
  
5. The owner/operator shall maintain a operations log for this unit current and on-site (or at a central location) for a minimum of five (5) years, and this log shall be provided to District, State and Federal personnel upon request. The log shall include, at a minimum, the information specified below:
  - a. Date of each use;
  - b. Duration of each use (in hours as indicated by the hour timer);
  - c. Daily, weekly, monthly and calendar year operation in terms of total hours, and
  - d. Fuel sulfur concentration (the owner/operator may use the fuel supplier's certification of sulfur content if it is maintained as part of this log). [Title 17 CCR 93116.4(c)]
  
6. This USEPA Tier 3 portable engine consists of a small fleet and may not be operated on or after January 1, 2029. [Title 17 CCR 93116.3(c)]. Additionally this USEPA Tier 3 portable engine may not be sold, or offered for sale, to an end user in California on or after January 1, 2029. The sale of engines for resale outside of California is not prohibited. [Title 17 CCR 93116.3(e)]
  
7. This engine is subject to the requirements of the Airborne Toxic Control Measure For Diesel Particulate Matter from Portable Engines Rated at 50 Horsepower and Greater (Title 17 CCR 93116). In the event of conflict between these conditions and the ATCM, the more stringent shall govern. [Title 17 CCR 93116]
  
8. Visible emissions from this equipment shall not exceed an opacity equal to, or greater than, twenty percent (20%) for a period aggregating more than three (3) minutes in any one (1) hour, excluding uncombined water vapor [District Rule 401]. This equipment shall not discharge air contaminants or materials constituting a nuisance to any considerable number of persons or to the public [District Rule 402]. Roadways, work areas and stockpiles shall be kept sufficiently moist to control fugitive dust, and no visible emissions shall extend beyond the property line of the emission source [District Rule 403]. Equipment to properly wet the material being processed shall be maintained in operable condition on-site and used as necessary to assure compliance with this condition. [District Rule 1302(C)(2)(a)]
  
9. A facility wide Comprehensive Emission Inventory (CEI) for all emitted criteria and toxic air pollutants must be submitted to the District, in a format approved by the District, upon District request. [District Rule 107(b), H&S Code 39607 & 44341-44342, and 40 CFR 51, Subpart A]