



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

INACTIVE

B012346

Inactive type Permit has no description information.

EXPIRES LAST DAY OF: NOVEMBER 2025

OWNER OF OPERATOR (Co. #86)

MAGTFTC MCAGCC
Box 788110, Bldg 1418
Twentynine Palms, CA 92278-8110

EQUIPMENT LOCATION (Fac. #3250)

USMC AGCC - USMC Recycling
Box 788110, Bldg. 1451
Twentynine Palms, CA 92278

Description:

DIESEL IC ENGINE, PORTABLE TUB GRINDER consisting of: Year of Mfg. 2015, US EPA Tier 4F, Engine Family FCPXL15.2HTF, CARB EO UR-001-0500. Exhaust stack diameter 0.417 ft, exhaust temp 111 degrees F, 696 dscfm.

One Caterpillar, Diesel fired internal combustion engine Model No. C15 ACERT and Serial No. n5100746, After Cooled, DEF Dosing System, Diesel Exhaust Fluid (DEF) Tank, Diesel Oxidation Catalyst, Electronic Control Module, Exhaust Gas Recirculation, Exhaust Gas Recirculation, Selective Catalytic Reduction, Selective Catalytic Reduction, Turbo Charged, producing 540 bhp with 6 cylinders at 2100 rpm while consuming a maximum of 28.5 gal/hr. This equipment powers a W.H.O. Manufacturing Grinder Model No. P12-56XSHD and Serial No. 1202, rated at TBD.

EMISSIONS RATES

Emission Type	Est. Max Load	Unit
CO	0.08	gm/bhp-hr
NOx	0.08	gm/bhp-hr
PM10	0.008	gm/bhp-hr
SOx	0.005	gm/bhp-hr
VOC	0.05	gm/bhp-hr

CONDITIONS:

1. This diesel engine, and any associated air pollution control equipment, shall be installed, operated, and maintained in strict accord with those recommendations of the manufacturer/supplier and in a manner consistent with safety and good air pollution control practices for minimizing emissions. Unless otherwise noted, this equipment shall also be operated in accordance with all data and specifications submitted with the application for this permit.

Fee Schedule: 1 (c) Rating: 540 bhp SIC: 9711 SCC: 20200102 Location/UTM(Km): 587E/3788N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

MAGTFTC MCAGCC
Box 788110, Building 1418

Twentynine Palms, CA 92278-8110

By: **COPY**
Brad Poiriez
Air Pollution Control Officer

[District Rule 1302]

2.This diesel ICE and its associated equipment cannot be operated at the same engine-print (spot) for more than 365 consecutive days, excluding time spent at a designated storage site when the equipment is not in use. This equipment must be moved within this facility or to another facility annually for a valid operational reason.

[Title 17 CCR 93116.2(a)(29)]

3.This unit shall only be fired on ultra-low sulfur diesel fuel whose sulfur concentration is less than or equal to 0.0015% (15 ppm) on a weight per weight basis per CARB Diesel or equivalent requirements; or alternative diesel fuel, or CARB diesel fuel utilizing fuel additives, that has been verified through the Verification Procedure for In-Use Strategies to Control Emissions from Diesel Engines.

[Title 17 CCR 93116.3(a)]

4.A non-resettable four-digit (9,999) hour timer shall be installed and maintained on this unit to indicate elapsed engine operating time.

[District Rule 1302(C)(2)(a) and Title 17 CCR 93116]

5.This equipment shall not be operated for more than 2912 hours in any one year (12 month rolling sum.)

[District Rule 1302]

6.The owner/operator shall maintain an operations log for this unit current and on-site (or at a central location) for a minimum of five (5) years, and this log shall be provided to District, State and Federal personnel upon request. The log shall include, at a minimum, the information specified below:

- a. Date of each use, location of each use (decimal degrees, xx.xxxx;-yyy.yyyyy) and duration of each use (in hours);
- b. Reason for use (regular use, testing & maintenance, emergency use, required emission testing);
- c. Calendar year operation in terms of fuel consumption (in gallons) or total hours (to assist in CEI data collection);
- d. Description of all repairs and/or maintenance actions on emission control systems; and,
- e. Fuel sulfur concentration (the o/o may use the supplier's certification of sulfur content if it is maintained as part of this log).

[District Rule 1302(C)(2)(a)]

7.Visible emissions from this system shall not exceed an opacity equal to or greater than twenty percent (20%) for a period aggregating more than three (3) minutes in any one (1) hour.

8.This unit shall not operate within 1000 feet of the outer boundary of any K-12 school for more than 45 days. Such operation will require the submittal of an application for a revised permit to operate so that the applicable requirements of the California Health and Safety Code Section 42301.6 will be met.

[District Rule 1302 and H&S Code 42301.6]

9.The fleet of portable diesel engines under control of this owner/operator are subject to the requirements of the Airborne Toxic Control Measure For Diesel Particulate Matter From Portable Engines Rated At 50 Horsepower and Greater (Title 17 CCR 93116). In the event of conflict between these conditions and the ATCM, the more stringent shall govern.

[Title 17 CCR 93116]

10.In each calendar year, the actual emissions of this facility shall be less than 20 tons NO_x, 20 tons VOC, and 12 tons PM₁₀ (SM80 Emission Rate). The owner/operator shall demonstrate compliance with this limit on an annual basis through the submission of the Comprehensive Emission Inventory Report (CEIR) to the District. Copies of the CEIR(s) must be kept and maintained on-site for at least five years and presented to District personnel upon request.

[District Rule 221; District Rule 107(b), H&S Code 39607 & 44341-44342, and 40 CFR 51, Subpart A]