



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

RENEWAL

B012984

Renewal type Permit has no description information.

EXPIRES LAST DAY OF: JUNE 2025

OWNER OF OPERATOR (Co.#2574)

Jess Ranch Health Care
11959 Apple Valley Rd.
Apple Valley, CA 92308

EQUIPMENT LOCATION (Fac.#3785)

Jess Ranch Health Care
11959 Apple Valley Road
Apple Valley, CA 92308

Description:

BOILERS, NATURAL GAS consisting of: One AJAX Boilers, rated at 1.375 MMBtu/hr. Model No. W6-1375, Serial No's. TBD either 90-42909 or 91-43036, and six tankless Navien boilers each rated 0.1999 MMBtu/hr. Model No. NPE-240S2 Serial No's: Boiler 1: 2089B2361439574 Boiler 2: 2089E2361469337 Boiler 3: 2089F2361479600 Boiler 4: 2089B2361439354 Boiler 5: 2069Z2391819358 Boiler 6: 2069A2381420405. Combined rating of 2.5744 MMBtu/hr.

CONDITIONS:

1. This equipment shall be installed, operated and maintained in strict accordance with those recommendations of the manufacturer/supplier and/or in a manner consistent with safety and good air pollution control practices for minimizing emissions. Furthermore, operation of this equipment shall be conducted in compliance with all data and specifications submitted with the application under which this permit is issued.

[District Rule 1303(B)]

2. This equipment is limited to using only commercially available natural gas for fuel.

[District Rule 431]

3. The owner/operator shall maintain an operations log for this equipment on-site and current for a minimum of two (2) years, and said log shall be provided to District personnel on request. The operations log shall include the following information at a minimum:

- Records of all maintenance, repairs, and tune-ups; and,
- Total fuel consumed on an annual basis: Fuel consumption can be calculated based on fuel purchase records, dedicated fuel meter readings, or other District approved method.

[District Rule 1520]

Fee Schedule: 2 (c)

Rating: 2574400 Btu

SIC: 8062

SCC: 10300603

Location/UTM(Km): 473E/3965N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

Jess Ranch Health Care
11959 Apple Valley Rd.
Apple Valley, CA 92308

By: **COPY**
Brad Poiriez
Air Pollution Control Officer

4.A facility wide Comprehensive Emission Inventory (CEI) for all emitted criteria and toxic air pollutants must be submitted to the District, in a format approved by the District, upon District request.
[District Rule 107(b), H&S Code 39607 & 44341-44342, and 40 CFR 51, Subpart A]