



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

INACTIVE

B013482

Inactive type Permit has no description information.

EXPIRES LAST DAY OF: JUNE 2020

OWNER OF OPERATOR (Co.#2482)

Zohnson & Co.
4195 Chino Hills Parkway, #171
Chino Hills, CA 91709

EQUIPMENT LOCATION (Fac.#3876)

Zohnson & Co.
17277 Columbus Street
Adelanto, CA 92301

Description:

DIESEL IC ENGINE, PORTABLE GENERATOR, CANNABIS (BLDG. C) consisting of: Year of Mfg. 2008, EPA Engine Family 8JDXL09.0102, EPA Tier 3

One John Deere, Diesel fired internal combustion engine Model No. 6090HF485 and Serial No. RG6090L039323, Direct Injected, Turbo Charged, Charge Air Cooler, producing 308 bhp with 6 cylinders at 1800 rpm while consuming a maximum of gal/hr. This equipment powers a Generac Generator Model No. SD230 and Serial No. 2098284, rated at 224 kW.

EMISSIONS RATES

Emission Type	Est. Max Load	Unit
CO	0.375	gm/bhp-hr
NOx	2.57	gm/bhp-hr
NOx+NMHC	2.7	gm/bhp-hr
PM10	0.09	gm/bhp-hr
PM2.5	0.09	gm/bhp-hr
SOx	0.005	gm/bhp-hr
VOC	0.14	gm/bhp-hr

CONDITIONS:

1. This diesel ICE and its associated equipment cannot be operated at this facility - Zohnson & Co. passed 6/10/2020. [Title 17 CCR 93116.2(a)(29)]

Fee Schedule: 1 (c)

Rating: 300 bhp

SIC: 2833

SCC: 20100102

Location/UTM(Km):
459E/3825N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

<p>Zohnson & Co. 4195 Chino Hills Parkway, #171 Chino Hills, CA 91709</p>

By: **COPY**
Eldon Heaston
 Air Pollution Control Officer

2. This nonroad Tier 3 compression-ignited internal combustion engine shall be installed, operated and maintained in strict accordance with those recommendations of the manufacturer/supplier and/or sound engineering principles which produce the minimum emissions of air contaminants. Unless otherwise noted, this equipment shall also be operated in accordance with all data and specifications submitted with the application for this permit.
[District Rule 204]

3. A non-resettable four-digit (9,999) hour timer shall be installed and maintained on this unit to indicate elapsed engine operating time.
[Title 17 CCR 93116.4(c)(2)(A)]

4. For purposes of this permit, pursuant to the requirements of 17 CCR 93116.3(c)(1), this engine is considered a small fleet and shall not operate in California on or after January 1, 2027.
[District Rule 204; 17 CCR 93116.3(c)(1)]

5. This engine shall not operate for more than 14 hours per day.
[District Rules 1302 and 1320]

6. This unit shall only be fired on ultra-low sulfur diesel fuel whose sulfur concentration is less than or equal to 0.0015% (15 ppm) per CARB Diesel or equivalent requirements.
[Title 17 CCR 93116.3(a)]

7. The owner/operator shall maintain an operations log for this unit current and on-site (or at a central location) for a minimum of five (5) years, and this log shall be provided to District, State and Federal personnel upon request. The log shall include, at a minimum, the information specified below:

- a. Date of each use and duration of each use (in hours);
- b. Reason for use (Regular use, testing & maintenance, emergency, required emission testing);
- c. Daily, Monthly and annual operation in terms of fuel consumption (in gallons) and total hours; and,
- d. Fuel sulfur concentration (the owner/operator may use the supplier's certification of sulfur content if it is maintained as part of this log).
- f. Location of operation, in latitude/longitude, accurate to 5 decimal places.

[District Rule 1302; 1320; Title 17 CCR 93116.4(c)]

8. This engine is subject to the requirements of Title 17 CCR 93116, the Airborne Toxic Control Measure (ATCM) for Diesel Particulate Matter from Portable Engines Rated at 50 Horsepower and Greater. In the event of a conflict between these conditions and the ATCM or NSPS, the more stringent requirements shall govern.
[District Rule 1302; Title 17 CCR 93116]

9. A facility wide Comprehensive Emission Inventory (CEI) for all emitted criteria and toxic air pollutants must be submitted to the District, in a format approved by the District, upon District request.
[District Rule 107(b), H&S Code 39607 & 44341-44342, and 40 CFR 51, Subpart A]