



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

INACTIVE

B013627

Inactive type Permit has no description information.

EXPIRES LAST DAY OF: JUNE 2026

OWNER OF OPERATOR (Co.#2550)

TrafFix Devices, Inc. dba Coast Rubber Products
12128 Yucca Road
Adelanto, CA 92301

EQUIPMENT LOCATION (Fac.#3965)

TrafFix Devices, Inc. dba Coast Rubber Products
12128 Yucca Road
Adelanto, CA 92301

Description:

BOILERS consisting of: Two (2) identical Parker Boiler Co. 48L Steam Boilers, Serial Numbers 52419 and 64060, rated at 1.995 MM Btu/hr Heat Input each, for a combined rating of 3.99 MM Btu/hr; equipped with Low NOx burners, and venting through an 18-inch diameter, 113-inch high Flue Duct.

CONDITIONS:

1. This equipment shall be installed, operated and maintained in strict accordance with those recommendations of the manufacturer/supplier and/or in a manner consistent with safety and good air pollution control practices for minimizing emissions. Furthermore, operation of this equipment shall be conducted in compliance with all data and specifications submitted with the application under which this permit is issued.
[District Rule 1303(B)]
2. This equipment is limited to using only PUC-Regulated pipeline quality natural gas for fuel.
[District Rules 431 and 1303(B)]
3. A non-resettable four-digit (9,999) hour timer shall be installed and maintained on these units to indicate elapsed unit operating time.
[District Rule 204]
4. The owner/operator shall maintain an operations log for this equipment on-site and current for a minimum of five (5) years, and log shall be provided to District personnel upon request. The operations log shall include, at a minimum, the following information:
 - a. Total operation time (hours per month and an annual total);

Fee Schedule: 2 (c)

Rating: 3990000 Btu

SIC: 3069

SCC: 10300603

Location/UTM(Km):
463E/3825N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

TrafFix Devices, Inc. dba Coast Rubber Products
160 Avenida La Pata
San Clemente, CA 92673

By: **COPY**
Eldon Heaston
Air Pollution Control Officer

- b. Total fuel consumed on an annual basis: This reading may be a separate reading for individual units or a combined reading for both units operating at this facility;
 - c. Date and results of all boiler tune-ups; and
 - d. Records of all maintenance and repair actions performed on boilers by nature and date.
- [District Rules 1157(E)(2)(c) and 1302(C)(2)(a)]

5. This equipment must be tuned at least once in every consecutive twelve month period, according to manufacturer's instructions.
[District Rules 1302 and 1320]

6. These units shall meet the following emission limits (corrected to 3% oxygen and on a dry basis):

- a. NO_x less than 30 ppmvd; and
- b. CO less than 400 ppmvd;

Although periodic source testing is not currently required, the District may require such testing to verify the above emission limits at their discretion. Until such time source testing is required, the owner/operator shall show compliance with these emission limits by providing expected emissions data from the burner manufacturer.

[District Rules 204 and 1303]

7. A facility wide Comprehensive Emission Inventory (CEI) for all emitted criteria and toxic air pollutants must be submitted to the District, in a format approved by the District, upon District request.

[District Rule 107(b), H&S Code 39607 & 44341-44342, and 40 CFR 51, Subpart A]