



## MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310  
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

### AUTHORITY TO CONSTRUCT

B014010

If construction is not completed by the expiration date of this permit, it may be renewed for one additional year upon payment of applicable fees. Any additional extension will require the written approval of the Air Pollution Control Officer. This Authority to Construct may serve as a temporary Permit to Operate provided the APCO is given prior notice of intent to operate and the Permit to Operate is not specifically denied.

### EXPIRES LAST DAY OF: SEPTEMBER 2025

#### OWNER OF OPERATOR (Co. #1584)

ComAV Technical Services LLC  
18438 Readiness Street  
Victorville, CA 92394

#### EQUIPMENT LOCATION (Fac. #2675)

ComAV Technical Services  
18438 Readiness Street  
Victorville, CA 92394

#### Description:

DIESEL IC ENGINE, PORTABLE GROUND POWER UNIT (GPU, Unit ID: GPU-11) consisting of: A certified Tier 4f diesel engine, EPA Family HPKXL07.0BN1, manufactured in 2017 and equipped with factory-installed emission controls. Exhaust flow is approximately 1829 scfm at 931 degrees Fahrenheit through a 6.67 foot tall by 3 inch diameter stack:

One Perkins, Diesel fired internal combustion engine Model No. 1206F-E70TTAG4 and Serial No. BN51865\*U001369B, Ammonia Oxidation Catalyst, Charge Air Cooler, Continuous Trap Oxidizer, Diesel Oxidation Catalyst, Direct Injected, Engine/Powertrain Control Module, Exhaust Gas Recirculation, Exhaust Gas Recirculation, Selective Catalytic Reduction, Selective Catalytic Reduction, Turbo Charged, producing 321 bhp with 6 cylinders at 1800 rpm while consuming a maximum of 16.5 gal/hr. This equipment powers an Advance GSE Corp Ground Power Unit Model No. AmpJet 180 AD180DG and Serial No. 1692BJJF112AB180BA100077, rated at 180 kVA.

#### EMISSIONS RATES

Emission Type	Est. Max Load	Unit
CO	0.969	gm/bhp-hr
NOx	0.201	gm/bhp-hr
NOx+NMHC	0.209	gm/bhp-hr
PM10	0.0015	gm/bhp-hr
PM2.5	0.0015	gm/bhp-hr
SOx	0.005	gm/bhp-hr
VOC	0.0075	gm/bhp-hr

Fee Schedule: 1 (c)

Rating: 321 bhp

SIC: 4581

SCC: 20100102

Location/UTM(Km): 473E/3820N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

ComAV Technical Services LLC  
18438 Readiness Street  
Victorville, CA 92394

By: **COPY**  
**Brad Poiriez**  
Air Pollution Control Officer

## CONDITIONS:

1.This equipment shall be installed, operated and maintained in strict accordance with those recommendations of the manufacturer/supplier and/or sound engineering principles which produce the minimum emissions of contaminants. Unless otherwise noted, this equipment shall also be operated in accordance with all data and specifications submitted with the application for this permit.  
[District Rule 1302(C)(2)(a)]

2.This engine shall only be fired on ultra-low sulfur diesel fuel whose sulfur concentration is less than or equal to 0.0015% (15 ppm) per CARB Diesel or equivalent requirements; or alternative diesel fuel or CARB diesel fuel utilizing fuel additives that has been verified through the Verification Procedure for In-Use Strategies to Control Emissions from Diesel Engines.  
[Title 17 CCR 93116.3(a)]  
Note: Use of CARB Certified ULSD fuel satisfies this requirement.

3.This engine and its associated equipment cannot be operated at the same engine-print (spot) for more than 365 consecutive days. This equipment must be moved for a valid business purpose annually.  
[District Rules 1302, 1303, and 1320 and Title 17 CCR 93116.2(a)(29)]

4.A non-resettable four-digit (9,999) hour timer shall be installed and maintained on this unit to indicate elapsed engine operating time.  
[District Regulation XIII - NSR; Title 17 CCR 93116.4(c)(2)(A)]

5.This engine shall not operate for more than 4,000 hours in any consecutive 12 month period. Before this limitation can be increased, the facility is required to submit to the District an application to modify the permit, which may trigger BACT review and may necessitate a Health Risk Assessment (HRA). In addition, public notice and/or a commenting period may be required.  
[District Rules 1302, 1303, and 1320]

6.This engine shall not be operated unless all of the following emission control systems are properly functioning:

- Diesel Oxidation Catalyst;
- Exhaust Gas Recirculation System;
- Continuous Trap Oxidizer;
- Electronic Control Module;
- Ammonia Oxidation Catalyst; and
- Selective Catalytic Reduction System;

Furthermore, no changes shall be made to any of the above systems unless done so by a factory certified technician.  
[District Rule 1302(C)(2)(a)]

7.The owner/operator shall maintain an operations log for this unit, current and on-site (or at a central location), for a minimum of five (5) years, and this log shall be provided to District, State and Federal personnel upon request. The log shall include, at a minimum, the information specified below:

- Date, location, and duration of each use (in hours);
- Monthly and consecutive 12 month period hour meter readings, including the dates of all monthly readings;
- Date of each maintenance action or repair on any equipment noted in Condition #6;
- Description of each maintenance action or repair on any equipment noted in Condition #6; and,
- Fuel sulfur concentration as required by condition #2 (you may use the supplier's certification of sulfur content if it is maintained as part of this log).

[District Regulation XIII - NSR]

8.This unit is subject to the requirements of the Airborne Toxic Control Measure (ATCM) for Portable Compression Ignition Engines (Title 17 CCR 93116). In the event of conflict between these conditions and the ATCM, the more stringent requirements shall govern.  
[District Rule 1302 and Title 17 CCR 93116]

9.This engine may be relocated throughout the Southern California Logistics Airport (SCLA) in support of operations without prior notification being sent to the District, but shall not be used within 1000 meters of any K-12 school, residence, hospital, or other sensitive receptor location. Sensitive receptor locations include, but are not limited to, hospitals, schools, and day care centers, and such other locations as the District board or California Air Resources Board may determine.

[District Rule 204 and H&S Code 42705.5(a)(5)]

10.A facility wide Comprehensive Emission Inventory (CEI) for all emitted criteria and toxic air pollutants must be submitted to the District, in a format approved by the District, upon District request.

[District Rule 107(b), H&S Code 39607 & 44341-44342, and 40 CFR 51, Subpart A]