



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

PERMIT TO OPERATE

B014070

Operation under this permit must be conducted in compliance with all information included with the initial application, initial permit condition, and conditions contained herein. The equipment must be maintained and kept in good operating condition at all times. This Permit to Operate or copy must be posted on or within 8 meters of equipment. If a copy is posted, the original must be maintained on site, available for inspection at all times.

EXPIRES LAST DAY OF: JULY 2026

OWNER OF OPERATOR (Co.#2)

CALNEV Pipe Line, LLC
1001 Louisiana Street
Houston, TX 77002-5089

EQUIPMENT LOCATION (Fac.#353)

CALNEV - Barstow Terminal
34277 Daggett-Yermo Road
Daggett, CA 92327

Description:

LUBRICITY AND CONDUCTIVITY SKID AND INJECTION SYSTEM consisting of: a 350-gallon tote and injection system for introducing product into biodiesel (B100), renewable diesel (R100) and, ultra low sulfur diesel (ULSD) product prior to the tanker loading systems for lubricity control.

CONDITIONS:

1. This equipment shall be installed, operated and maintained in strict accordance with those recommendations of the manufacturer/supplier and/or sound engineering principles which produce the minimum emissions of contaminants. Unless otherwise noted, this equipment shall also be operated in accordance with all data and specifications submitted with the application for this permit. [District Rules 204 and 1303]
2. The owner/operator must ensure that all of the components of the facility and this system; including but not limited to: tanks, flanges, seals, pipes, pumps, valves, meters, connectors, etc.; are maintained as Vapor Tight and Liquid Tight and operated so as to prevent excess Organic Liquid drainage during transfer, storage and handling operations. [District Rule 462(D)]
3. The lubricity/conductivity product used in this system must have a maximum vapor pressure of less than 0.2 psia. [District Rule 1303(B) - Offset limiting]

Fee Schedule: 7 (i)

Rating: 1 device

SIC: 5171

SCC: 2501050000

Location/UTM(Km):
510E/3859N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

CALNEV Pipe Line, LLC
1001 Louisiana Street
Houston, TX 77002-5089

By: **COPY**
Eldon Heaston
Air Pollution Control Officer

4. The emissions of this system were offset using Emission Reduction Credits; therefore, any change or modification to this system, including the capacity of the product tote, or the lubricity/conductivity product outside the parameters listed in condition 3, must be made in consultation with the District prior to modification. This system is exempt from District Rule 463 pursuant to section (A)(2)(b), as this system current capacity is less than 19,815 gallons.
[District Rule 1302(C)(2)(a)]

5. The total volume of product transferred (injected) from this system must not exceed 9,125 gallons per any twelve-month period.
[District Rule 1303(B) - Offset limiting]

6. A non-resettable meter, either mechanical or digital, shall be installed to indicate hourly and daily transfer of product from this system, in gallons.
[District Rule 1303(B) - Compliance Demonstration]

7. The owner/operator shall maintain a throughput log for each day of operation (from midnight to midnight) which shall include, as a minimum, the following information. This log shall be kept current and on-site (or at a central location) for a minimum of five (5) years, and shall be provided to District, State and Federal personnel upon request:

- a. Product Name and CAS Number or SDS Identifier;
- b. Amount transferred (injected), in gallons;
- c. Monthly totals of each product transferred (injected);
- d. Running 12 consecutive month totals of product transferred (injected); and,
- e. Records of all repairs made, descriptions of leaks, and maintenance performed on this equipment per District Rule 462.

[District Rule 1303(B) - Compliance Demonstration]

8. A facility wide Comprehensive Emission Inventory (CEI) for all emitted criteria and toxic air pollutants must be submitted to the District, in a format approved by the District, annually and upon District request.
[District Rule 107(b), H&S Code 39607 & 44341-44342, and 40 CFR 51, Subpart A]