



**MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT**

14306 Park Avenue Victorville, CA 92392-2310  
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

**RENEWAL**

B015290

Renewal type Permit has no description information.

**EXPIRES LAST DAY OF: MARCH 2026**

**OWNER OF OPERATOR (Co.#2261)**

Clark Pacific Precast, LLC  
9367 Holly Rd.  
Adelanto, CA 92301

**EQUIPMENT LOCATION (Fac.#3628)**

Clark Pacific Adelanto Precast Plant  
9367 Holly Rd.  
Adelanto, CA 92301

**Description:**

DIESEL IC ENGINE, PORTABLE GENERATOR consisting of: A Certified Tier 4f diesel engine, EPA Family HSZXL03.0RXB, CARB Executive Order U-R-006-0437, manufactured in 2017. Exhaust flow is approximately 272 ACFM at 572 degrees Fahrenheit through a 3-foot high exhaust stack.

One Isuzu Motors Limited, Diesel fired internal combustion engine Model No. BR-4JJ1X and Serial No. , Turbo Charged, After Cooled, Selective Catalytic Reduction, Diesel Oxidation Catalyst, Electronic Control Module, Selective Catalytic Reduction, Ammonia Oxidation Catalyst, producing 95 bhp with 4 cylinders at 1800 rpm while consuming a maximum of 4.39 gal/hr. This equipment powers a MQ Multipiquip Generator Model No. DCA-70SSIU4F and Serial No. TBD, rated at 70 kW.

**CONDITIONS:**

1. This EPA Tier 4 compression-ignited internal combustion engine (engine) shall be installed, operated and maintained in strict accordance with those recommendations of the manufacturer/supplier and/or sound engineering principles which produce the minimum emissions of air contaminants. Unless otherwise noted, this equipment shall also be operated in accordance with all data and specifications submitted with the application for this permit.  
[District Rule 204]
2. This diesel IC engine must be CARB or EPA certified to meet Tier 4F nonroad compression ignition standards.  
[District Rule 1320 and 1520]
3. The owner/operator shall maintain, on-site, an emissions statement from the engine manufacturer, CARB, or EPA which demonstrates the engine complies with Condition 2.

Fee Schedule: 1 (b)

Rating: 95.2 bhp

SIC: 3272

SCC: 20200102

Location/UTM(Km):  
459E/3826N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

Clark Pacific Precast, LLC  
Attn: Siah Gaye  
  
Adelanto, CA 92301

By: **COPY**  
**Eldon Heaston**  
Air Pollution Control Officer

[District Rule 204]

4. This engine and its associated equipment cannot be operated at the same footprint (spot) for more than 365 consecutive days. (This system must be moved within this facility or moved to another facility annually).

[Title 17 CCR 93116.4(b)(2)(A)]

5. This engine shall not operate within 55 meters (180 feet) of the facility's outer fence-line.

[District Rules 1320 and 1520]

6. This engine shall only be fired on ultra-low sulfur diesel fuel whose sulfur concentration is less than or equal to 0.0015% (15 ppm) per CARB Diesel or equivalent requirements.

[Title 17 CCR 93116.3(a)]

7. A non-resettable four-digit (9,999) hour timer shall be installed and maintained on this unit to indicate elapsed engine operating time.

[Title 17 CCR 93116.4(b)(2)(A)]

8. The combined hours of operation for engines under District Permits B013458, B015014, B015289, B015290, B015291 and B015292 shall not exceed 15,000 hours per year.

[District Rule 1320 and 1520]

9. The owner/operator must maintain a operations log for this unit current and on-site (or at a central location) for a minimum of two (2) years, and this log must be provided to District, State and Federal personnel upon request. The log must include, at a minimum, the information specified below:

a. Date and location of each use (in Lat xx.xxxxx/Lon yyy.yyyyy format) and duration of each use (in hours);

b. Distance (in feet or meters) from facility's outer fence-line;

c. Annual hours operated (summarized monthly);

d. Fuel sulfur concentration (the owner/operator may use the supplier's certification of sulfur content if it is maintained as part of this log);

e. Documentation such as CARB Executive Order or US EPA Certificate of Conformity for each engine operated pursuant to the terms of this permit; and

f. US EPA Engine Family Name of current rented engine.

[District Rules 1302 and Title 17 CCR 93116.4]

10. This portable diesel-fueled engine is subject to the Airborne Toxic Control Measure For Diesel Particulate Matter from Portable Engines Rated at 50 Horsepower and Greater (Title 17 CCR 93116 - Portable ATCM). In the event of conflict between these conditions and the requirements of the Portable ATCM, the more stringent requirements shall govern.

11. A facility wide Comprehensive Emission Inventory Report (CEIR) for all emitted criteria and toxic air pollutants must be submitted to the District, in a format approved by the District, upon District request.

[District Rule 107(b), Health & Safety Code 39607 & 44341-44342, 17 CCR 93400 et seq., and 40 CFR 51, Subpart A]