



## MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310  
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

### PERMIT TO OPERATE

C000140

Operation under this permit must be conducted in compliance with all information included with the initial application, initial permit condition, and conditions contained herein. The equipment must be maintained and kept in good operating condition at all times. This Permit to Operate or copy must be posted on or within 8 meters of equipment. If a copy is posted, the original must be maintained on site, available for inspection at all times.

**EXPIRES LAST DAY OF: MAY 2026**

#### **OWNER OF OPERATOR (Co. #2239)**

CalPortland Company  
19409 National Trails Hwy  
Oro Grande, CA 92368

#### **EQUIPMENT LOCATION (Fac. #3)**

CalPortland Oro Grande  
19409 National Trails Hwy  
Oro Grande, CA 92368

#### **Description:**

BAGHOUSE 121BF101 consisting of: a Nor-Blo Model 624A-40' baghouse with polyester felt bags whose total filter area is a minimum of 7333 square feet, equipped with a 50 hp fan generating 22,000 cfm of flow at 90 degrees Fahrenheit (for a maximum air to cloth ratio of 3.0:1). This unit serves the secondary crushing system (B000137).

#### **CONDITIONS:**

1. This equipment must be installed, operated and maintained in strict accordance with those recommendations of the manufacturer/supplier and/or sound engineering principles, which produce the minimum emissions of contaminants. Unless otherwise noted, this equipment must also be operated in accordance with all data and specifications submitted with the application for this permit. [District Rule 204]

2. This baghouse shall be operated concurrently with belt conveyor 110BC102, belt conveyor 121BC101, belt conveyor 121BC103, and secondary crusher 121CR101 under B000137  
[District Rules 204; 1303(A)]

3. The o/o shall conduct a minimum program of inspection and maintenance on this equipment. The o/o shall maintain current and on-site for five (5) years a log of the following information, which shall be provided to District personnel upon request:

- (a) Weekly reading of baghouse pressure drop, date and value;
- (b) Monthly baghouse stack observation date and result (using USEPA Method 22, and USEPA Method 9 if visible emissions are detected);
- (c) Quarterly bag and bag suspension system inspection date and results;

Fee Schedule: 7 (h)

Rating: 1 device

SIC: 3241

SCC: 30500610

Location/UTM(Km): 469E/3830N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

CalPortland Company  
Attn: Catalina Elias  
  
Oro Grande, CA 92368

By: **COPY**  
**Brad Poiriez**  
Air Pollution Control Officer

(d) Date of bag replacements; and,  
(e) Date and nature of any system repairs.  
[District Rules 1303(A); 1203(D)(1)(d)(ii); 40 CFR Part 60.674(c)]

4.This baghouse shall discharge no more than 1.89 pounds per hour of PM10 at a maximum concentration of 0.01 grains/dscf at the operating conditions given in the above description (BACT). This equipment does not require a regularly scheduled emission compliance test. However, emission compliance testing may be required at the discretion of the District.  
[District Rules 404; 1303(A); 40 CFR 60.672]

5.This unit shall be equipped with a device to measure the pressure differential across the bags (manometer).  
[District Rule 1303(A)]

6.The o/o shall maintain on-site a minimum inventory of replacement bags that assures compliance with these conditions.  
[District Rule 1303(A)]