



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

PERMIT TO OPERATE

C000561

Operation under this permit must be conducted in compliance with all information included with the initial application, initial permit condition, and conditions contained herein. The equipment must be maintained and kept in good operating condition at all times. This Permit to Operate or copy must be posted on or within 8 meters of equipment. If a copy is posted, the original must be maintained on site, available for inspection at all times.

EXPIRES LAST DAY OF: JULY 2026

OWNER OF OPERATOR (Co.#879)

Searles Valley Minerals Utilities
82090 First Street
Trona, CA 93562

EQUIPMENT LOCATION (Fac.#1735)

SVMU - Utilities Argus Facility
82090 First Street
Trona, CA 93562

Description:

SCRUBBER WET, ARGUS BOILER NO. 26 consisting of: Serves Argus Boiler No. 26 (District permit B000554) and includes the following, which are common to both this scrubber and scrubber covered by C000558: Scrubber Recycle Pumps, 2 @ 100 hp ea (one is spare) Scrubber Make-up Pumps, 2 @ 40 hp ea (one is spare)

CONDITIONS:

1. This equipment shall be operated concurrently with Boiler No. 26 (B000554) and its ESP (C000559).
[District Rule 204]
2. This equipment shall be operated/maintained in strict accord with the recommendations of the manufacturer/supplier and/or sound engineering principles.
[District Rule 204]
3. The maintenance/inspection program shall be in accordance with the manufacturer's recommendations and/or sound engineering principles.
[District Rule 204]
4. The owner/operator shall maintain a log of all inspections, repairs, and maintenance on this equipment and submit it to District, state or federal personnel upon request. The log shall be kept for a minimum period of five (5) years.
[District Rule 204]

Fee Schedule: 7 (h)

Rating: 1 device

SIC: 4911

SCC: 10200219

Location/UTM(Km):
465E/3957N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

Searles Valley Minerals Utilities
P.O. Box 367
Trona, CA 93592-0367

By: **COPY**
Eldon Heaston
Air Pollution Control Officer