



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

INACTIVE

C002129

Inactive type Permit has no description information.

EXPIRES LAST DAY OF: DECEMBER 2016

OWNER OF OPERATOR (Co.#500)

ACE Cogeneration Company
12801 S Mariposa Street
Trona, CA 93562

EQUIPMENT LOCATION (Fac.#1051)

ACE Cogeneration Company
12801 S Mariposa Street
Trona, CA 93562

Description:

BAGHOUSE (LIMESTONE TRUCK UNLOADING AND CRUSHING-LIMESTONE HANDLING SYSTEM (B002128)) consisting of: Flex-Kleen, model no 120-WMWC-660 (III), serial no. 10-95-31748 baghouse equipped with a 125 hp induced draft fan generating 42,000 acfm with an exhaust temperature of 70 deg F, 14,520 sq ft of spun bonded Polyester pulse pleat filters (2.9:1 air to cloth ratio), a 1.5 hp screw feeder and a 3/4 hp rotary feeder.

CONDITIONS:

1. This baghouse shall operate concurrently with the equipment described as the Limestone Truck Unloading and Crushing and Limestone Handling System (B002128).
2. The owner/operator (o/o) shall conduct a minimum program of inspection and maintenance (frequencies may be changed upon successful demonstration to the District that less frequent monitoring is equally effective). The o/o shall maintain current and on-site for five (5) years a log of this information which shall be provided to District personnel upon request:
 - a. Pressure differential across the bags (weekly);
 - b. Baghouse stack visible emissions determination (monthly);
 - c. Bags and bag suspension system inspection (quarterly); and
 - d. Bag replacements and repairs.
3. The o/o shall install, operate and maintain this dust collector in strict accord with those recommendations of the manufacturer/supplier, and sound engineering principles which produce minimum emissions of air contaminants.

Fee Schedule: 7 (h)

Rating: 1 device

SIC: 4911

SCC: 30510298

Location/UTM(Km): 465E/3958N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

ACE Cogeneration Company
12801 S Mariposa Street
Trona, CA 93562

By: **COPY**
Brad Poiriez
Air Pollution Control Officer

- 4.The o/o shall maintain an inventory of replacement bags on-site at all times which will ensure compliance with applicable Rules of District Regulation IV.
- 5.The o/o shall install and maintain a device which measures the pressure differential across the bags if one has not been provided with this unit.
- 6.This baghouse shall discharge no more than 1.08 lb/hour of particulate at a maximum concentration of 0.003 grain/dscf at the operating conditions given in the above description.