



**MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT**

14306 Park Avenue Victorville, CA 92392-2310  
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

**INACTIVE**

C003299

Inactive type Permit has no description information.

**EXPIRES LAST DAY OF: DECEMBER 2006**

**OWNER OF OPERATOR (Co.#500)**

ACE Cogeneration Company  
12801 S Mariposa Street  
Trona, CA 93562

**EQUIPMENT LOCATION (Fac.#1051)**

ACE Cogeneration Company  
12801 S Mariposa Street  
Trona, CA 93562

**Description:**

BAGHOUSE consisting of: Bin vent serving Fly Ash Re-injection Silo (B002131); a Flex-Kleen, model no 58 BVBS-9 II, serial no. E32585; 65 sq ft cloth area; 4:1 cloth to air ratio; gas flow of 260 ACFM, maximum @ 275 degrees F.

**CONDITIONS:**

1. The owner/operator (o/o) shall install, operate and maintain this dust collector in strict accord with those recommendations of the manufacturer/supplier, and sound engineering principles which produce minimum emissions of air contaminants.
2. The o/o shall institute a program of maintenance which embraces at least weekly visible emission determinations, monthly visual inspections of all associated equipment (inclusive of the bags and their suspension systems) and regular (to be determined with experience with this unit) measurements of the pressure differential across the bags.
3. The o/o shall log all the items in 2 above in addition to the bag replacements, repairs and non-scheduled maintenance. The log shall be kept current, on-site for a minimum of 2 years and provided to District personnel on request.
4. The o/o shall maintain an inventory of replacement bags on-site at all times which will ensure compliance with applicable Rules of District Regulation IV.
5. This baghouse shall operate concurrently with Fly Ash Re-injection Silo under valid District permit number B002131.

Fee Schedule: 7 (h)

Rating: 1 device

SIC: 4911

SCC: 30510298

Location/UTM(Km):  
465E/3958N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

ACE Cogeneration Company  
12801 S Mariposa Street  
Trona, CA 93562

By: **COPY**  
**Eldon Heaston**  
Air Pollution Control Officer