



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

INACTIVE

C009139

Inactive type Permit has no description information.

EXPIRES LAST DAY OF: MAY 2010

OWNER OF OPERATOR (Co.#46)

Victorville, City of
14343 Civic Drive
Victorville, CA 92392-2399

EQUIPMENT LOCATION (Fac.#2723)

Victorville - Foxborough
12961 Enterprise Way
Victorville, CA 92395

Description:

SELECTIVE CATALYTIC REDUCTION SYSTEM (CTG-SCR-03) consisting of: SCR unit reducing CTG NOx from 25 to 2 ppmvd with anhydrous ammonia, and CO from 50 to 6 ppmvd and VOC to 2.5 ppmvd with an oxidation catalyst. This unit serves the gaseous fueled Solar Taurus 60 turbine generator set CTG-03 (B009136) and Coen Duct Burner DB-03.

CONDITIONS:

1. Operation of this equipment shall be conducted in compliance with all data and specifications submitted with the application under which this permit is issued unless otherwise noted below.
2. This equipment shall be operated and maintained in strict accord with the recommendations of its manufacturer or supplier and/or sound engineering principles.
3. This equipment shall be operated concurrently with the combustion turbine generator covered in valid permit B009136 and the duct burner with valid permit B009142.
4. Ammonia shall be injected whenever the selective catalytic reduction system has reached or exceeded 550 degrees Fahrenheit except for periods of equipment malfunction. Except during periods of startup, shutdown and malfunction, ammonia slip shall not exceed 5 ppmv dry at 15% oxygen, averaged over three hours.

Fee Schedule: 7 (h)

Rating: 1 device

SIC: 9199

SCC: 20100201

Location/UTM(Km): 473E/3820N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

Victorville, City of
Public Works - Fleet Division

Victorville, CA 92392-2399

By: **COPY**
Brad Poiriez
Air Pollution Control Officer