

MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park AvenueVictorville, CA92392-2310 760.245.1661 -- 800.635.4617 -- FAX760.245.2022

INACTIVE

C009597

Inactive type Permit has no description information.

EXPIRES LAST DAY OF: JULY 2009

OWNER OF OPERATOR (Co.#46)

Victorville, City of 14343 Civic Drive

EQUIPMENT LOCATION (Fac. #2666)

Victorville - SCLA Power Plant #1 17951 Phantom West Victorville,CA92394

Description:

EXHAUST TREATMENT SYSTEM (ICE-SCR-02) consisting of:Attainment Technologies GreenGuard exhaust gas recirculation (EGR) and non-selective catalytic reduction (NSCR) system. This unit serves gaseous fueled internal combustion generator set ICE-02 (B009593).

CONDITIONS:

Victorville, CA92392-2399

- 1. Operation of this equipment shall be conducted in compliance with all data and specifications submitted with the application under which this permit is issued unless otherwise noted below.
- 2. This equipment shall be operated and maintained in strict accord with the recommendations of its manufacturer or supplier and/or sound engineering principles.
- 3. This equipment shall be operated concurrently with the internal combustion engine generator set with valid MDAQMD permit B009593.

Fee Schedule:7 (h)

Rating:1device

SIC:4911

SCC:20200204

Location/UTM(Km):473E/3820N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

Page 1 of 1

Victorville, City of Public Works - Fleet Division

Victorville, CA92392-2399

By: **COPY**

Air Pollution Control Officer