



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

INACTIVE

C010462

Inactive type Permit has no description information.

EXPIRES LAST DAY OF: JANUARY 2010

OWNER OF OPERATOR (Co.#1661)

Environmental Construction Group, Inc
3271 E 19th St
Signal Hill, CA 90755

EQUIPMENT LOCATION (Fac.#2821)

Environmental Construction Group, Inc
District Wide
MDAQMD, CA 92392

Description:

HEPA VAC consisting of: Pullman Holt 102, Serial # 12086 with primary and secondary filters. A Dacron filter bag covers the entire spacer sleeve and HEPA filter for three-stage filtration. Dacron material sheds dust to maintain maximum vacuum efficiency. The HEPA filter is 99.97% efficient for the collection of all particles whose mean diameter is greater than or equal to 0.3 microns. This unit exhausts at the rate of 110 cfm.

CONDITIONS:

1. The HEPA filters shall meet UL585 and UL900 class 2 requirements.
2. This air filtration device shall be operated and maintained in strict accord with those recommendations of the manufacturer.
3. This device may, at the discretion of the owner/operator, be used on any asbestos removal project in this District with proper 10-day notification consistent with Federal Register 40 CFR part 61. Proper notification is: written and telephone communication a minimum of 10 working days before actual placement of this permitted equipment on the new site.

Fee Schedule: 7 (h)

Rating: 1 device

SIC: 1795

SCC: 31100202

Location/UTM(Km):
473E/3956N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

Environmental Construction Group, Inc
3271 E 19th St
Signal Hill, CA 90755

By: **COPY**
Eldon Heaston
Air Pollution Control Officer