



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

INACTIVE

C014196

Inactive type Permit has no description information.

EXPIRES LAST DAY OF: JUNE 2022

OWNER OF OPERATOR (Co.#2693)

Moji Group, LLC
16425 Beaver Road
Adelanto, CA 92301

EQUIPMENT LOCATION (Fac.#4115)

Moji Group, LLC
16425 Beaver Road
Adelanto, CA 92301

Description:

ODOR CONTROL/AIR FILTRATION SYSTEM, CANNABIS consisting of: An odor control filtration system consisting of 17 CAN-LITE 10" 1300 CFM granular activated carbon air filters. Each filter measures 14" Outer Diameter x 40" Height, with a sorbent depth of 2". The filters exhaust to atmosphere through exhaust fans rated 1/4 hp, 1019 CFM with an exhaust stack diameter of 10" each.

CONDITIONS:

1. These air pollution control devices shall be installed, operated and maintained in strict accordance with those recommendations of the manufacturer/supplier and/or sound engineering principles which produce the minimum emissions of air contaminants. Unless otherwise noted, this equipment shall also be operated in accordance with all data and specifications submitted with the application for this permit.
[District Rule 204]

2. The filters used in these Air Filtration Systems shall have the manufacturer's recommended prefilters properly installed whenever the system is in operation.
[District Rule 1302]

3. Odors from this equipment shall be non-detectable and the activated carbon filters must be changed any time breakthrough has occurred. The owner/operator shall conduct quarterly odor detection checks at the exhaust of the above described equipment to ensure that breakthrough has not occurred. If odors are detected, the filters must be changed immediately. If the exhaust of this equipment is not accessible, then the filters must be replaced at a minimum once every quarter.
[District Rules 204 and 402]

Fee Schedule: 7 (h)

Rating: 1 device

SIC: 191

SCC: 30299998

Location/UTM(Km):
457E/3823N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

Moji Group, LLC
16425 Beaver Road
Adelanto, CA 92301

By: **COPY**
Eldon Heaston
Air Pollution Control Officer

4. The owner/operator must take all steps necessary to preclude odor migration from this facility, including but not limited to, carbon filter change outs when breakthrough has occurred, keeping doors and windows closed to the maximum extent possible, isolating odor-emitting activities from other areas of the buildings through closing doors and windows, and operating all air filters continuously during cultivation activities.

[District Rule 402]

5. A log pertaining to the operation of this equipment shall be kept for a period of two (2) years, and must be made available upon request of District personnel. This log shall contain, as a minimum, the following information:

- a. The date and time of each activated carbon filter replacement;
- b. Results of quarterly odor monitoring checks; and
- c. A copy of the manufacturer's specification for control efficiency for the activated carbon filters.

[District Rule 204]

6. A facility wide Comprehensive Emission Inventory (CEI) for all emitted criteria and toxic air pollutants must be submitted to the District, in a format approved by the District, upon District request.

[District Rule 107(b), H&S Code 39607 & 44341-44342, and 40 CFR 51, Subpart A]