



MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

DELINQUENT

C015048

Delinquent type Permit has no description information.

EXPIRES LAST DAY OF: MAY 2025

OWNER OF OPERATOR (Co.#2938)

2119 Building, Inc.
7381 Foothill Blvd
Tujunga, CA 91042

EQUIPMENT LOCATION (Fac.#4363)

2119 Building
2590 Mercantile Way
Barstow, CA 92311

Description:

ODOR CONTROL AND SUPPRESSANT SYSTEM, CANNABIS consisting of: Composed of an odor maskant system comprised of a FOG Co misting system which injects a neutralizing formula (Cannabusters concentrate) into the mist.

CONDITIONS:

1. These air pollution control devices shall be installed, operated and maintained in strict accordance with those recommendations of the manufacturer/supplier and/or sound engineering principles which produce the minimum emissions of air contaminants. Unless otherwise noted, this equipment shall also be operated in accordance with all data and specifications submitted with the application for this permit. [District Rule 204]

2. Odors from this equipment shall be non-detectable. The owner/operator shall conduct quarterly odor detection checks at the exhaust of the above described equipment to ensure that breakthrough has not occurred. If odors are detected, the odor misting system must be properly adjusted, until the odors are no longer detectable. [District Rules 204 and 402]

3. The owner/operator must take all steps necessary to preclude odor migration from this facility, including but not limited to, keeping doors and windows closed to the maximum extent possible, isolating odor-emitting activities from other areas of the buildings through closing doors and windows, and operating all odor control equipment continuously during cultivation activities. [District Rule 402]

4. A log pertaining to the operation of this equipment shall be kept for a period of two (2) years, and must be made available upon request of District personnel. This log shall contain, as a minimum, the following information:
a. The date and time of each odor additive refill;

Fee Schedule: 7 (h)

Rating: 1 device

SIC: 2833

SCC: 30299999

Location/UTM(Km): 493E/3856N

This permit does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This permit cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This permit must be renewed by the expiration date above. If billing for renewal fee required by Rule 301(c) is not received by expiration date above, please contact the District.

2119 Building, Inc.
7381 Foothill Blvd
Tujunga, CA 91042

By: **COPY**
Brad Poiriez
Air Pollution Control Officer

b. Results of quarterly odor monitoring checks.
[District Rule 204]

5.A facility wide Comprehensive Emission Inventory (CEI) for all emitted criteria and toxic air pollutants must be submitted to the District, in a format approved by the District, upon District request.
[District Rule 107(b), H&S Code 39607 & 44341-44342, and 40 CFR 51, Subpart A]