



## MOJAVE DESERT AIR QUALITY MANAGEMENT DISTRICT

14306 Park Avenue Victorville, CA 92392-2310  
760.245.1661 -- 800.635.4617 -- FAX 760.245.2022

### CANNABIS ODOR COMPLIANCE PLAN AUTHORIZATION

COCPP000026

This California Business & Professions Code Division 10 Compliance Plan (Cannabis Odor Compliance Plan) is authorized in response to District Rule 302(J)(5). This authorization is designed to enforce the provisions of Division 26 of the California Health & Safety Code and applicable District Rules and Regulations. Operations covered by this authorization must be conducted in compliance with all information included with the initial filing and requirements specified below. Equipment referenced by this authorization must be maintained and kept in good operating condition at all times. This authorization shall be maintained on site at the location referenced below at all times.

**EXPIRES LAST DAY OF: JUNE 2025**

#### OWNER OF OPERATOR (Co.#2693)

Moji Group, LLC  
16425 Beaver Road  
Adelanto, CA 92301

#### EQUIPMENT LOCATION (Fac.#4115)

Moji Group, LLC  
16425 Beaver Road  
Adelanto, CA 92301

#### Description:

CANNABIS ODOR COMPLIANCE PLAN consisting of: A facility licensed under the California Business & Professions Code Division 10 which will start operations after 4/1/2021 and includes cannabis cultivation and replaceable carbon canisters venting within the building.

#### EQUIPMENT

Capacity	Equipment Description
15454	COCPP Facility Square feet
7	CAN-LITE 10" D by 40" H 48 pound replaceable carbon canisters handling 1019 cfm each and venting within the building through a 10" diameter stack
5	CAN-LITE 14" D by 40" H 68 pound replaceable carbon canisters handling 1019 cfm each and venting within the building through a 14" diameter stack
17	CAN-LITE 10" D by 40" H 48 pound replaceable carbon canisters handling 1019 cfm each and venting outside the building through a 14" diameter stack

#### REQUIREMENTS:

1. The owner/operator shall ensure that this facility does not discharge from any source whatsoever such quantities of odor which cause

Fee Schedule: 13 (a)

Rating: 1 sq. ft.

SIC: 191

SCC: 30299999

Location/UTM(Km): 457E/3823N

This plan does not authorize the emission of air contaminants in excess of those allowed by law, including Division 26 of the Health and Safety Code of the State of California and the Rules and Regulations of the District. This plan cannot be construed as permission to violate existing laws, ordinances, statutes or regulations of this or other governmental agencies. This plan must be renewed by the expiration date above. If billing for renewal fee required by Rule 302 is not received by expiration date above, please contact the District.

Moji Group, LLC  
16425 Beaver Road  
Adelanto, CA 92301

By: **COPY**  
**Brad Poiriez**  
Air Pollution Control Officer

injury, detriment, nuisance or annoyance to any considerable number of persons or to the public. Compliance with this condition shall be verified by either: (a) no detectable odor at any exterior vent, exterior discharge or exterior container associated with this facility, or (b) no detectable odor at any portion of the fenceline or property boundary of this facility.